

National Emission Standards for Hazardous Air Pollutants for
Reciprocating Internal Combustion Engines (RICE Rule) Training Module
40 CFR 63 Subpart ZZZZ
Script- Major Source New Limited Use Engine >500 Horsepower

NARRATOR:

[Slide 2:]

Welcome to the Connecticut Department of Energy & Environmental Protection's Online Training for the National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines, also known as the RICE Rule!

This tool is designed to help owners and operators of reciprocating internal combustion engines, also known as RICE, determine their requirements under 40 CFR Section 63, subpart ZZZZ. By answering the successive questions, your specific requirements have been estimated. Please note that they may not be complete, and refer any questions to your local authority.

[Slide 3:]

We have established that you own or operate a new, limited use engine, greater than 500 horsepower, located at a major source, that is not subject to New Source Performance Standards. Keep in mind, your engine is only considered limited use if it operates less than 100 hours per year. Now, let's discuss your requirements.

The rule requires you to submit an Initial Notification within 120 days after the effective date of the rule or 120 days after construction or reconstruction of the unit. A sample Initial Notification of Applicability form can be found on the EPA RICE Compliance web page. The address for this site will be provided later in this module.

The Initial Notification must include the following information:

- The owner or operator's name and address.
- The address where the affected source is physically located.
- The relevant standard which requires submission of a notification, and your compliance date.
- A short description of the engine, including its size, nature, design, method of operation, and the types of emission points within the affected source that are subject to the applicable standard, along with the hazardous air pollutants emitted.
- An indication as to whether the engine is located at an area or major source of hazardous air pollutants; and
- A statement indicating that the unit has no additional requirements along with an explanation of the exclusion. In this instance, the exclusion is based on the fact that the engine operates as a limited use engine if it has a site rating of greater than 500 horsepower at a major source.

[Slide 4:]

All notifications and reports should be sent to EPA Region 1 at the address shown here.

[Slide 5:]

You must be in compliance with all applicable requirements by the date shown here.

[Slide 6:]

If you would like more information about the RICE rule, please visit the EPA RICE Compliance web page at the address provided. This site provides resources such as Q and A documents, fact sheets, sample notification forms, and recordings of webinars, all of which are designed to help you comply with this rule.

[Slide 7:]

Let's summarize your requirements under this rule.

- You must submit an Initial Notification of Applicability within 120 days after the effective date or after construction or reconstruction.
- Your engine must be in compliance with all requirements of this rule by the date shown on screen.