


STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH



Jewel Mullen, M.D., M.P.H., M.P.A.
Commissioner

Dannel P. Malloy
Governor
Nancy Wyman
Lt. Governor

April 2, 2014

Anastasia O'Hara
Norwesco/Snyder, Inc.
P.O. Box 439
4365 Steiner Street
St. Bonifacius, MN 55375-0439

Subject: Norwesco/Snyder Inc. Tank Approvals

Model #'s: CT 1000 LP, CT 1250 LP, and CT 1500 LP

Dear Ms. O'Hara:

This Department has reviewed the technical documentation and specifications for the three (3) low-profile polyethylene tanks noted above. The tank submittal has been made at the request of both Norwesco Inc. and Snyder Inc. As such, tanks shall be permanently marked with the name NORWESCO/SNYDER, INC., along with their model number and other pertinent information. The tanks have effective capacities of 1000, 1250 and 1500 gallons, respectively.

The *Technical Standards for Subsurface Sewage Disposal Systems* (Technical Standards) stipulates that this Department must approve non-concrete septic tanks and pump chambers. The information submitted documents that all three (3) tanks meet the minimum requirements in the Technical Standards for non-concrete septic tanks. Therefore, this Department hereby APPROVES the CT 1000 LP, CT 1250 LP, and CT 1500 LP for use as either a septic tank or a pump chamber.

The Technical Standards stipulates that non-concrete septic tanks must be installed in strict adherence with the manufacturer's installation instructions, and proper bedding, backfill and compaction must be confirmed with each tank installation. All non-concrete septic tanks distributed in Connecticut must include installation instructions, and each approved tank manufacturer is responsible to provide this Department with the most current installation instructions, tank specifications, and supporting documentation. Product modifications require prior approval from this Department.




Phone: (860) 509-7296 • Fax: (860) 509-7295 • VP: (860) 899-1611
410 Capitol Avenue, P.O. Box 340308 – MS #51SEW
Hartford, Connecticut 06134-0308
www.ct.gov/dph

Affirmative Action/Equal Opportunity Employer and Provider
If you require aid or accommodation to full and fairly enjoy this publication,
please phone (860) 509-7293

A copy of this letter will be provided to all local health departments in Connecticut, and to our Code Advisory Committee which includes representation from sewage system installers and designer associations. This letter will also be posted on our program's website, and may be reproduced as a means of notifying distributors of this Department's approval. The CT 1000 LP, CT 1250 LP, and CT 1500 LP septic tanks shall be added to Technical Standards Appendix D (Approved Non-Concrete Tanks) during its next revision. As with all product approvals, this Department's approval should not be considered an endorsement of the product.

Sincerely,



Robert W. Scully, PE
Supervising Sanitary Engineer
Environmental Engineering Program

C: David Kelley, Snyder Industries Inc., P.O. Box 4583, Lincoln NE 68504
Local Directors of Health
Chief Sanitarians
Code Advisory Committee
Professional Engineers