

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719103	PRIDES CORNER FARMS - POTTING SHED	NC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
122 WATERMAN ROAD			1				
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **WELL 1 (WSF ID: 20050)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2026	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719103	PRIDES CORNER FARMS - POTTING SHED	NC	50	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
122 WATERMAN ROAD			1				
Towns Served: LEBANON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LDRM1	SLOP SINK	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20050	WELL 1	2	WELL	A				
47847	POTTING SHED TREATMENT STATION							

Certified Operator Information

Water System Facility: POTTING SHED TREATMENT STATION (WSF ID: 47847)			
Facility Classification:			Certification Expiration
Operator Name	Operator Type	Certification(s)	3/31/2025
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	

Contact Information

Name		Organization			Job Title	
Mr. Mark Sellew		Pride's Corner Farmhouse			Owner	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
122 Waterman Road				Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-642-7535		860-642-4155				

Contact Role(s): Legal Contact, Owner						
Name		Organization			Job Title	
Mr. Christian Joseph		Prides Corner Farms, Inc.			Site Compliance Mgr	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
122 Waterman Road				Lebanon	CT	06268
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-468-6025		860-642-2027		860-642-7535	cjoseph@pridescorner.com	

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710014	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 1	NC	140	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BH87387	KITCHEN SINK	A	Y			
		BK05449	RANGER HOUSE KITCHEN	A	Y			
		BK79872	SERVICE CTR KITCHEN	A	Y			
		BK81563	SERVICE CTR KITCHEN	A	Y			
		BK81565	LEFT BATHROOM SINK	A	Y			
		BN14584	RANGER HOUSE KITCHEN	A	Y			
		BN14587	SERVICE CTR RIGHT BA	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21211	WELL 1	2	WELL	A				

Certified Operator Information

--

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710014	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 1	NC	140	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization			Job Title		
Girl Scouts of America, Inc.							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
340 Washington Street					Hartford	CT	06106
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-522-0163							

Contact Role(s): Legal Contact, Owner

Name		Organization			Job Title		
Ms. Deb Asetta		Girl Scouts of Connecticut			Chef Financial/Admi		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		

Contact Role(s): Owner

Name		Organization			Job Title		
Ms. Mary Beth Corcoran		Girl Scouts of Connecticut					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710024	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 2	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24	10/1-10/31	Complete		
	4/1/25 - 6/30/25	5/1-6/30			
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25	10/1-10/31			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SEASONAL START UP COMPLETION	5/1/2025	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
REVISED TOTAL COLIFORM RULE (RTCR)	5/2/23 - 5/9/23	3	6/5/2025		6/15/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BH87193	FROST FREE TAP	A	Y			
		BJ11209	HEALTH CENTER KITCHEN	A	Y			
		BK05448	HEALTH CTR BATHROOM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21212	WELL 2	2	WELL	A				
61962	ATM STORAGE TANK (400-GALLON)							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710024	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 2	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: DISTRIBUTION SYSTEM			<i>Certification Expiration</i>
<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization			Job Title		
Girl Scouts of America, Inc.							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
340 Washington Street					Hartford	CT	06106
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-522-0163							

Contact Role(s): Legal Contact, Owner							
Name		Organization			Job Title		
Ms. Deb Asetta		Girl Scouts of Connecticut			Chef Financial/Admi		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		

Contact Role(s): Owner							
Name		Organization			Job Title		
Ms. Mary Beth Corcoran		Girl Scouts of Connecticut					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		

Contact Role(s): **Administrative Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710034	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 3	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				10			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)				1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Physical Parameters (PPS)				1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SEASONAL START UP COMPLETION	5/1/2025	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification Required</i>	<i>Public Notification Performed</i>	<i>PN Certification Due to DPH</i>	<i>PN Certification Received</i>
REVISED TOTAL COLIFORM RULE (RTCR)	5/2/23 - 5/8/23	3	6/6/2025		6/16/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BJ11211	WHITE PRE HAND WASH	A	Y			
		BJ91401	4 CORNERS	A	Y			
		BJ91403	WHITE PINES	A	Y			
		BJ91404	WATERFRONT	A	Y			
		BJ91405	OFFICE	A	Y			
		BK05447	DISTRIBUTION TAP	A	Y			
		BN21690	RAMBLERS REST SINK	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710034	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 3	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				10			
Towns Served: LEBANON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
21213	WELL 3	2	WELL	A				
57398	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: DISTRIBUTION SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization			Job Title		
Girl Scouts of America, Inc.							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
340 Washington Street					Hartford	CT	06106
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-522-0163							
Contact Role(s): Legal Contact, Owner							
Name		Organization			Job Title		
Ms. Deb Asetta		Girl Scouts of Connecticut			Chef Financial/Admi		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		
Contact Role(s): Owner							
Name		Organization			Job Title		
Ms. Mary Beth Corcoran		Girl Scouts of Connecticut					
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
20 Washington Avenue					North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-239-2922	3321				property@gsofct.org		
Contact Role(s): Administrative Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710034	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 3	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				10			
Towns Served: LEBANON							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710044	FIRE SAFETY COMPLEX	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
GOSHEN HILL ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/14/2023	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21214	WELL	2	WELL	A				
60931	WELL 2	2	WELL 2	A				
62890	WATER SOFTENER							

Contact Information

Name		Organization			Job Title			
Lebanon								
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0710044	FIRE SAFETY COMPLEX	NC	25	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
GOSHEN HILL ROAD				1				
Towns Served: LEBANON								
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Kevin Cwikla			Town of Lebanon			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
579 Exeter Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-642-6100	1			860-334-1009	firstselectman@lebanonct.gov			
Contact Role(s): Administrative Contact, Legal Contact								
Please note the following:								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710064	GOSHEN HILL CHURCH	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CHURCH ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21215	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title			
Miss Maureen D McCall			Goshen Hill Church			Clerk			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
157 Church Road						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-642-5537				860-642-7150	goshenhillchurch1729@gmail.com				
Contact Role(s): Administrative Contact, Legal Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710064	GOSHEN HILL CHURCH	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
CHURCH ROAD				1			
Towns Served: LEBANON							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710074	LAKE WILLIAMS CAMPGROUND	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1742 EXETER ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 4/30/25	4/15-4/30	
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25	10/1-10/15	

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24	4/15-10/15	Complete
	1/1/25 - 12/31/25	4/15-10/15	
	1/1/26 - 12/31/26	4/15-10/15	

Water System Facility: **WELL #2 (WSF ID: 21217)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	10/1/24 - 12/31/24	10/1-10/15	Complete
	4/1/25 - 6/30/25	4/15-6/30	
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25	10/1-10/15	

Water System Facility: **WELL #3 (WSF ID: 60568)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/24 - 12/31/24	10/1-10/15	Complete
	4/1/25 - 6/30/25	4/15-6/30	
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25	10/1-10/15	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710074	LAKE WILLIAMS CAMPGROUND	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1742 EXETER ROAD				1			
Towns Served: LEBANON							

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4
Start Date: 4/1/2019		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21217	WELL #2	2	WELL	A				
59533	TREATMENT PLANT							
60568	WELL #3	2	WELL 3	A				

Contact Information

Name			Organization			Job Title			
Mr. John Oleksiw			Lake Williams Campground Assoc			President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 571						Manchester		CT	06045
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-908-1842					lwca.inc.pc@gmail.com				

Contact Role(s): **Legal Contact, Owner**

Name			Organization			Job Title			
Mr. Franklin Pilicy			Pilicy & Ryan, Pc			Attorney			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
365 Main Street						Watertown		CT	06795
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-274-0018		860-274-0061			pilicylaw@pilicy.com				

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0710074	LAKE WILLIAMS CAMPGROUND	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
1742 EXETER ROAD				1				
Towns Served: LEBANON								
Name			Organization			Job Title		
Ms. Jody L. Weller			Lake Williams Campground Assoc			Treasurer		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
5 Shaw Cove			Suite 200			New London	CT	06320
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-908-1842			860-908-1842	860-367-3476	admin@lwcainc.onmicrosoft.com			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710084	LEBANON COMMUNITY HOUSE	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 207 AND ROUTE 87				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Nitrite (1041)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/14/2023	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21218	WELL	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710084	LEBANON COMMUNITY HOUSE	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 207 AND ROUTE 87				1			
Towns Served: LEBANON							

Contact Information

Name			Organization			Job Title		
Lebanon								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Kevin Cwikla			Town of Lebanon			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
579 Exeter Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-642-6100	1			860-334-1009	firstselectman@lebanonct.gov			

Contact Role(s): **Administrative Contact, Legal Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710094	MARKET ON THE GREEN	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
199 WEST TOWN STREET				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25				
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25				
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25				
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Nitrite (1041)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21219	WELL	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710094	MARKET ON THE GREEN	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
199 WEST TOWN STREET				1			
Towns Served: LEBANON							

Contact Information

Name			Organization			Job Title			
Mr. Peter Alba			Pirates Properties LLC			Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
224 Mansfield City Road						Mansfield		CT	06250
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-931-1258				860-576-1423					

Contact Role(s): **Owner**

Name			Organization			Job Title			
Mr. Jason Stearns			Stearns Enterprises LLC			Business Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
199 West Town Street						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
813-475-0907				860-924-8310	jastearns74@gmail.com				

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710104	TRUMBULL LIBRARY	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
580 EXETER ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/14/2023	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21220	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title		
Lebanon								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0710104	TRUMBULL LIBRARY	NC	25	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
580 EXETER ROAD				1				
Towns Served: LEBANON								
Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Kevin Cwikla			Town of Lebanon			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
579 Exeter Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-642-6100	1			860-334-1009	firstselectman@lebanonct.gov			
Contact Role(s): Administrative Contact, Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710124	LEBANON TOWN HALL	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 207 AND ROUTE 87				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/14/2023	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21221	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title		
Lebanon								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0710124	LEBANON TOWN HALL	NC	25	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
ROUTE 207 AND ROUTE 87				1				
Towns Served: LEBANON								
Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Kevin Cwikla			Town of Lebanon			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
579 Exeter Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-642-6100	1			860-334-1009	firstselectman@lebanonct.gov			
Contact Role(s): Administrative Contact, Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0710154	ST FRANCIS OF ASSISI	NC	25	P	GW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST TOWN STREET			1			

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21224	WELL	2	WELL	A				
58291	PRESSURE STORAGE							

Contact Information

Name		Organization			Job Title		
Reverend Mark Masnicki		St Francis of Assisi Church			Pastor		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
67 West Town Street					Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-642-6711		860-642-4032			parishoffice@guardianangelsparishofcolchester.		
Contact Role(s): Administrative Contact, Legal Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0710154	ST FRANCIS OF ASSISI	NC	25	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST TOWN STREET			1			
Towns Served: LEBANON						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710174	THE LOG CABIN RESTAURANT	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
383 TRUMBULL HIGHWAY (ROUTE 87)				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)			1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)			1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	5/5/2019	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	1/1/19 - 3/31/19	3	5/30/2020		6/9/2020	
Physical Parameters M&R Violation	1/1/19 - 3/31/19	3	5/30/2020		6/9/2020	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21226	WELL 1	2	WELL 1	A				
59754	WELL 2	2	WELL 2	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710174	THE LOG CABIN RESTAURANT	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
383 TRUMBULL HIGHWAY (ROUTE 87)				1			
Towns Served: LEBANON							

Contact Information

Name			Organization			Job Title			
Mr. Robert D'eliseo			The Log Cabin Restaurant			Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
389 Route 87						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-456-7663				860-716-2205	rdeliseo@sbcglobal.net				

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Name			Organization			Job Title			
Lebanon Properties LLC									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
383 Trumbull Hgwy						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710184	WATERS EDGE CAMPGROUND	NC	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
271 LEONARD BRIDGE ROAD				150			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)				1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25			

Physical Parameters (PPS)				1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25			

Water System Facility: ENTRY POINT - LOWER SAFARI WELL (WSF ID: 00701)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - LOWER SAFARI WELL (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	7/1/04 - 9/30/04	2	2/9/2005		2/19/2005	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
		OKS	OFFICE KITCHEN SINK	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - LOWER SAFARI WELL	3	EP - LOWER SAFARI WE	A				
57171	LOWER SAFARI WELL	2	LOWER SAFARI WELL	A				

Contact Information

Name			Organization			Job Title			
Mr. Brian Korten			Waters Edge Campground			Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
271 Leonard Bridge Rd						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-642-7470				860-933-4317	office@watersedgencampground.com				
Contact Role(s): Administrative Contact, Legal Contact, Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710184	WATERS EDGE CAMPGROUND	NC	60	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
271 LEONARD BRIDGE ROAD				150			
Towns Served: LEBANON							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710194	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 4	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

Physical Parameters (PPS)			1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SEASONAL START UP COMPLETION	5/1/2025	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
REVISED TOTAL COLIFORM RULE (RTCR)	5/2/23 - 5/8/23	3	6/5/2025		6/15/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BJ11213	KITCHEN SINK	A	Y			
		BK05446	DINING HALL KITCHEN	A	Y			
		BN23624	DINING HALL	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710194	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 4	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
23000	WELL #4	2	WELL	A				
57396	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: DISTRIBUTION			
Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization			Job Title	
Girl Scouts of America, Inc.						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
340 Washington Street				Hartford	CT	06106
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-522-0163						
Contact Role(s): Owner						
Name		Organization			Job Title	
Ms. Deb Asetta		Girl Scouts of Connecticut			Chef Financial/Admi	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
20 Washington Avenue				North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-239-2922	3321				property@gsofct.org	
Contact Role(s): Owner						
Name		Organization			Job Title	
Ms. Mary Beth Corcoran		Girl Scouts of Connecticut				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
20 Washington Avenue				North Haven	CT	06473
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-239-2922	3321				property@gsofct.org	
Contact Role(s): Administrative Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0710194	GIRL SCOUTS OF CT - CAMP LAUREL - WELL 4	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 CLUBHOUSE ROAD				1			
Towns Served: LEBANON							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719114	LEBANON SENIOR CENTER	NC	51	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST TOWN STREET				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	12/14/2023	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55625	WELL 1	2	WELL 1	A				

Contact Information

Name			Organization			Job Title		
Lebanon								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0719114	LEBANON SENIOR CENTER	NC	51	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
WEST TOWN STREET				1				
Towns Served: LEBANON								
Contact Role(s): Owner								
Name			Organization			Job Title		
Mr. Kevin Cwikla			Town of Lebanon			First Selectman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
579 Exeter Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-642-6100	1			860-334-1009	firstselectman@lebanonct.gov			
Contact Role(s): Administrative Contact, Legal Contact								
Please note the following:								
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.								
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.								
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.								

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719124	REDEEMER EVANGELICAL LUTHERAN CHURCH	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
321 VILLAGE HILL ROAD				1			
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55806	WELL 1	2	WELL 1	A				

Contact Information

Name			Organization			Job Title			
Reverend Scott Schuett			Redeemer Lutheran Church			Pastor			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
321 Village Hill Rd						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-423-4320		860-450-1064		860-208-2194	Pastor@rlclebanon.org				
Contact Role(s): Administrative Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0719124	REDEEMER EVANGELICAL LUTHERAN CHURCH	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
321 VILLAGE HILL ROAD				1				
Towns Served: LEBANON								
Name			Organization			Job Title		
Mr. Charles Bender			Redeemer Lutheran Church			Head Trustee		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
322 Village Hill Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-423-6859				860-423-9322				
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719144	GRAND LAKE SPA AND HOTEL	NC	29	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1667 EXETER ROAD						3	
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
50001	WELL 1	2	WELL 1	A				
62640	ATMOSPHERIC STORAGE							
62641	BOOSTER PUMP							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719144	GRAND LAKE SPA AND HOTEL	NC	29	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1667 EXETER ROAD						3	
Towns Served: LEBANON							

Contact Information

Name			Organization			Job Title			
Ms. Avni Martinaj			Grand Lake Spa And Hotel						
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
12 Powder Mill Lane						North Granby		CT	06060
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-805-9633				860-656-5028	martinajgroupinvestmentsllc@gmail.com				

Contact Role(s): **Administrative Contact, Owner**

Name			Organization			Job Title			
Mr. Ram Martinaj									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
12 Powder Mill Lane						North Granby		CT	06060
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-805-9633									

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719134	903 EXETER RD - LEBANON	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1			

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
60439	WELL 2	2	WELL 2	A				

Contact Information

Name			Organization			Job Title			
Mr. Vincent Derosa			Village Market Place			Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 28						Watertown		CT	06795
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-491-1404		860-945-8726		203-437-1090					
Contact Role(s): Administrative Contact, Legal Contact, Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719134	903 EXETER RD - LEBANON	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1			

Towns Served: LEBANON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719154	FIRST BAPTIST CHURCH OF LEBANON	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
694 TRUMBULL HIGHWAY						1	
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 58704)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
58704	WELL 1	2	WELL 1	A				
58708	TREATMENT PLANT							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719154	FIRST BAPTIST CHURCH OF LEBANON	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
694 TRUMBULL HIGHWAY						1	
Towns Served: LEBANON							

Contact Information

Name			Organization			Job Title			
Mr. Darwin Gebbe			First Baptist Church Lebanon			Trustee			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 231						Lebanon		CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-642-2569					darwin@pd-properties.com				

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0719174	LOST OAK VINEYARDS, LLC	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
95 BENDER ROAD						2	
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Physical Parameters (PPS)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
63076	WELL #1	2	WELL #1	A				
63079	TREATMENT PLANT							

Contact Information

Name			Organization			Job Title		
Ms. Julie Chalifoux			Lost Oak Vineyards, LLC					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
78 Bender Road						Lebanon	CT	06249
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-490-1795					julie.r.chalifoux@gmail.com			
Contact Role(s): Administrative Contact, Legal Contact, Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0719174	LOST OAK VINEYARDS, LLC	NC	25	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
95 BENDER ROAD					2	
Towns Served: LEBANON						

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule