

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040044</b>	<b>GLOBAL PARTNERS LP</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
170 TAFTVILLE- OCCUM ROAD				1			
Towns Served: NORWICH							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WELL (WSF ID: 21814)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21814	WELL	2	WELL	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040044</b>	<b>GLOBAL PARTNERS LP</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
170 TAFTVILLE- OCCUM ROAD				1			
Towns Served: NORWICH							

## Contact Information

Name			Organization			Job Title			
<b>Mr. Jeff McCullough</b>			Global Partners, Lp			Env. Project Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 549290			800 South Street, Suite 500			Waltham		MA	02453
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
781-250-7369					jeff.mccullough@globalp.com				

Contact Role(s): **Legal Contact**

Name			Organization			Job Title			
<b>Mr. Jack Cerra</b>			Atlas Technical Consultants			Sr Environmental Tec			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
290 Roberts Street			Suite 301			East Hartford		CT	06108
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-614-1983					jack.cerra@oneatlas.com				

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1040054	CHURCH OF JESUS CHRIST OF LATTER DAY SAI	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
597 SCOTLAND ROAD				1			
Towns Served: NORWICH							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21815	WELL	2	WELL	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040054</b>	<b>CHURCH OF JESUS CHRIST OF LATTER DAY SAI</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
597 SCOTLAND ROAD				1			
Towns Served: NORWICH							

## Contact Information

Name			Organization			Job Title			
<b>Mr. Roy B. McDaniel</b>			Natural Resources-Special Proj			Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
50 East North Temple St			Mfd 12Th Floor			Salt Lake City		UT	84150
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
801-240-4656		801-240-2913			mcdanielrb@ldschurch.org				

Contact Role(s): <b>Legal Contact, Owner</b>									
Name			Organization			Job Title			
<b>Ms. Christine Spencer</b>			Church of Jesus Christ of Lds			Hartford Admin Asst			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
130 South St						Cromwell		CT	06516
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-635-4035		860-835-4036			spencerca@churchofjesuschrist.org				

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1040064	NORWICH AESTHETIC DENTISTRY	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164 OTROBANDO AVENUE				1			
Towns Served: NORWICH							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040064</b>	<b>NORWICH AESTHETIC DENTISTRY</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164 OTROBANDO AVENUE				1			

Towns Served: NORWICH

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrite (1041)</b>	<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>
	<i>Collection Period</i>
	<i>Compliance Status</i>
	1/1/25 - 12/31/25
	1/1/26 - 12/31/26
	Complete

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21816	WELL	2	WELL	A				

## Contact Information

Name		Organization			Job Title			
<b>Dr. Edward C. Yates</b>		Norwich Aesthetic Dentsitry			Dentist-Owner			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
164 Otrobando Avenue						Norwich	CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-889-6445		860-889-5572		860-961-6221	yatesrecords@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040084</b>	<b>NORWICH WORSHIP CENTER</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
165 LAWLER LANE				1			

Towns Served: NORWICH

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21818	WELL	2	WELL	A				

## Contact Information

Name			Organization			Job Title			
<b>Mr. Michael Maixner</b>									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
165 Lawler Lane						Norwich		CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
Contact Role(s):		<b>Legal Contact</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1040084</b>	<b>NORWICH WORSHIP CENTER</b>	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
165 LAWLER LANE				1				
Towns Served: NORWICH								
Name			Organization			Job Title		
<b>Mr. Jefferey R. Sharp</b>			Norwich Worship Center			Senior Pastor/Pre.		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
165 Lawler Lane						Norwich	CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-822-9522	11	860-822-6678		860-334-0651	pastor@norwichworshipcenter.org			
Contact Role(s): <b>Administrative Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040104</b>	<b>7-ELEVEN #32524</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
152 TAFTVILLE-OCCUM ROAD				1			
Towns Served: NORWICH							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21820	WELL	2	WELL	A				

## Contact Information

Name			Organization			Job Title			
<b>Mr. Dave Goodman</b>			Olde Northeast Realty Lp			Administrator			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
22 Christy's Drive			Suite 4			Brockton		MA	02301
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
508-427-6111		508-427-4333							
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1040104</b>	<b>7-ELEVEN #32524</b>	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
152 TAFTVILLE-OCCUM ROAD				1				
Towns Served: NORWICH								
Name			Organization			Job Title		
<b>Christy's Realty Limited Partnership</b>								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P. O. Box 711			C/O Southland Cofp-Tax Dept Loc 125			Dallas	TX	75221
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): **Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1040134	THE NORWICH FISH & GAME ASSOC., INC.	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
44 BROWNING ROAD				1			
Towns Served: NORWICH							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 11/30/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	11/23/24 - 11/28/24		Complete		
	4/26/25 - 5/1/25		Complete		

<b>Total Coliform (3100)</b>		<b>3 temporary routine (TR) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24				
	5/1/25 - 5/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT - WELL #2 (WSF ID: 00701)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT - WELL 2 (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility: **WELL #2 (WSF ID: 54488)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL #2 (2)	11/22/24 - 11/28/24		Complete		
	4/25/25 - 5/1/25		Complete		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	11/25/2021	
L1 ASSESSMENT (MULTIPLE TC+)	5/30/2025	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1040134</b>	<b>THE NORWICH FISH &amp; GAME ASSOC., INC.</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
44 BROWNING ROAD				1			
Towns Served: NORWICH							

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Total Coliform MCL Violation	4/1/11 - 6/30/11	2	8/10/2011		8/20/2011	
Total Coliform MCL Violation	7/1/11 - 7/31/11	2	9/15/2011		9/25/2011	
Total Coliform M&R Violation	12/1/24 - 12/31/24	3	2/10/2026		2/20/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELL #2	3	ENTRY POINT - WELL 2	A				
54488	WELL #2	2	WELL #2	A				
62279	TREATMENT PLANT							

## Contact Information

Name			Organization			Job Title			
<b>Norwich Fish &amp; Game Association, Inc.</b>									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
44 Browning Road						Norwich		CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-887-3174									

Contact Role(s): <b>Owner</b>									
Name			Organization			Job Title			
<b>Mr. Jan M. Schneider</b>			Norwich Fish & Game			2008 House Chairman			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
44 Browning Road						Norwich		CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-433-7285				860-887-3174	jschneid@EBMAIL.GDEB.COM				

Contact Role(s): <b>Administrative Contact</b>									
Name			Organization			Job Title			
<b>Ms. Amy Sipuleski</b>									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
290 High Street						Baltic		CT	06330
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
			860-608-5869						

Contact Role(s): **Legal Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1040134</b>	<b>THE NORWICH FISH &amp; GAME ASSOC., INC.</b>	NC	25	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
44 BROWNING ROAD				1				
Towns Served: NORWICH								
Name			Organization			Job Title		
<b>Mr. Brent Al</b>			Norwich Fish & Game			House Chair		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
44 Browning Road						Norwich	CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-303-0861					ogees228365@yahoo.co m			
Contact Role(s): <b>Legal Contact, Owner</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1049024</b>	<b>MOHEGAN PARK - GROUP PAVILION</b>	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PARK CENTER RD / MOHEGAN PARK RD						1	
Towns Served: NORWICH							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>			<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24	4/1-12/31	Complete
	1/1/25 - 12/31/25	4/1-12/31	
	1/1/26 - 12/31/26	4/1-12/31	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
50021	WELL 1	2	WELL 1	A				

## Contact Information

Name			Organization			Job Title			
Mr. Patrick McLaughlin			City of Norwich			City Engineer			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Norwich Public Works Dept.			50 Clinton Ave			Norwich		CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-823-3798		860-823-3788		860-333-7216	pmclaughlin@cityofnorwich.org				
Contact Role(s): <b>Administrative Contact, Legal Contact</b>									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1049024</b>	<b>MOHEGAN PARK - GROUP PAVILION</b>	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PARK CENTER RD / MOHEGAN PARK RD						1	
Towns Served: NORWICH							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1049034</b>	<b>MOHEGAN PARK - DOG POUND</b>	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PARK CENTER RD / MOHEGAN PARK RD						1	
Towns Served: NORWICH							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>			<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>			<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24	4/1-12/31	Complete
	1/1/25 - 12/31/25	4/1-12/31	
	1/1/26 - 12/31/26	4/1-12/31	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
50031	WELL 1	2	WELL 1	A				

## Contact Information

Name			Organization			Job Title			
Mr. Peter Nystrom			City of Norwich			Mayor			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Norwich City Hall			100 Broadway			Norwich		CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-823-3743		860-885-2914			pnystrom@cityofnorwich.org				
Contact Role(s): <b>Administrative Contact, Legal Contact</b>									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1049034</b>	<b>MOHEGAN PARK - DOG POUND</b>	NC	25	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
PARK CENTER RD / MOHEGAN PARK RD						1	
Towns Served: NORWICH							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**