

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>2 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>2 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
TWN HALL 530 MAIN ST (03382)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
98 STEELE ROAD (03385)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
<b>Total Coliform (3100)</b>		<b>2 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30			
	1/1/26 - 12/31/28	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>2 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Physical Parameters (PPS)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT-BLACK BRIDGE WELL (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

  

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

  

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

  

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

  

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

  

<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Monitoring Requirements

**Water System Facility: ENTRY POINT-BLACK BRIDGE WELL (WSF ID: 00700)**

**Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSF ID: 00701)**

**Net Gross Alpha (4000) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Uranium (4006) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Combined Radium-226/228 (4010) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Inorganic Chemicals (IOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

**Nitrate And Nitrite (NOX) 1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

**Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS) 1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **ENTRY POINT-PINE MEADOW WELL (WSF ID: 00701)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PINE MEADOW (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: **PINE MEADOW WELL (WSF ID: 1211)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PINE MEADOW WELL 1 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **BLACK BRIDGE WELL (WSF ID: 1470)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BLACK BRIDGE WELL (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

--

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Water System Facility: ENTRY POINT-BLACK BRIDGE WELL (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 5/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

### Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 5/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	03382	TWN HALL 530 MAIN ST	A	Y	1	Y	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		03383	ACR 234 MAIN ST	A	Y	N		
		03384	11 CHURCH STREET	A	Y	3		
		03385	98 STEELE ROAD	A	Y	3		Y
		2350-1	50 HIGH STREET	A	Y	3		
		2350-10	50 WICKET STREET	A	Y	3		
		2350-11	8 COTTAGE STREET	A	Y	3		
		2350-13	11 BROOK ST	A	Y	1		
		2350-14	96 HOLCOMB HILL RD	A	Y	1		
		2350-15	76 COTTAGE STREET	A	Y	1		
		2350-16	21-23 COTTAGE ST	A	Y	2		
		2350-2	16 STEELE ROAD	A	Y	3		
		2350-3	56 HIGH STREET	A	Y	3		
		2350-4	48 PROSPECT STREET	A	Y	3		
		2350-5	15 LOOMIS HEIGHTS	A	Y	3		
		2350-6	59 COTTAGE STREET	A	Y	3		
		2350-7	24 PROSPECT STREET	A	Y	3		
		2350-8	38 PROSPECT STREET	A	Y	3		
		2350-9	15 CHURCH STREET	A	Y	3		
		2352	RVR RUN 238 MAIN ST	A	Y	3		
		2359-16	21-23 COTTAGE STREET	A	Y	2		
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB9367	8 BRIDGE ST	A		3		
		PB9368	8 CARTER ST	A		3		
		PB9369	10 COTTAGE ST	A		3		
		PB9370	32 COTTAGE ST	A		3		
		PB9371	16 GREENWOODS RD	A		3		
		PB9372	45 HIGH ST	A		1		
		PB9373	27 HIGHLAND AVE	A		3		
		PB9374	28 HILLSIDE AVE	A		3		
		PB9375	55 HOLCOMB HILL	A		3		
		PB9376	6 JOHNNYCAKE LN	A		3		
		PB9377	34 LOOMIS HTS	A		3		
		PB9378	24 PROSPECT ST	A		1		
		PB9379	51 RESERVOIR RD	A		3		
		PB9380	78 TOWN HILL RD	A		3		
		PB9381	31 CHURCH ST	A		3		
		PB9382	37 CHURCH ST	A		3		
		PB9383	341 MAIN ST	A		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB9384	16 TEN ST	A		3		
		PB9385	32 WICKETT ST	A		3		
		PB9386	50 WICKETT ST	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-BLACK BRIDGE WELL	3	EP - BLACK BRIDGE	A				
00701	ENTRY POINT-PINE MEADOW WELL	3	EP - PINE MEADOW	A				
1211	PINE MEADOW WELL	2	PINE MEADOW WELL 1	A				
1470	BLACK BRIDGE WELL	2	BLACK BRIDGE WELL	A				
36435	TREATMENT PLANT - BLACK BRIDGE							
36436	PINE MEADOW TREATMENT PLANT							
45522	GREENWOODS INDUSTRIAL PARK TANK 1							
52373	GREENWOODS INDUSTRIAL PARK TANK 2							
52375	INTERCONNECTION - CT0640011 - RESERVOIR							
52379	BLACK RIDGE TP PUMP STATION							

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MEYERS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
COLANGELO JR., JOSEPH M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2025

**Water System Facility: TREATMENT PLANT - BLACK BRIDGE (WSF ID: 36435)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026
RYLANDER, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

**Water System Facility: PINE MEADOW TREATMENT PLANT (WSF ID: 36436)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026
RYLANDER, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	<b>C</b>	<b>1,872</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			124	43	8		

Towns Served: NEW HARTFORD

## Contact Information

Name		Organization		Job Title		
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct		Vp-Supply & Utility		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Aquarion Water Company of Ct		505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0920041	LITTLE BROOK RD PROPERTY OWNERS ASSN	C	64	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16				

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25				
	7/1/25 - 12/31/25				
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete		
	1/1/25 - 12/31/27				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920041</b>	<b>LITTLE BROOK RD PROPERTY OWNERS ASSN</b>	C	64	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			16				

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	4	
<b>Start Date:</b> 1/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>	<b>Compliance Status:</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>	
	12/1/2024 - 12/31/2024			
	1/1/2025 - 1/31/2025			
	2/1/2025 - 2/28/2025			
	3/1/2025 - 3/31/2025			
	4/1/2025 - 4/30/2025			

## Other Compliance Schedules

<b>Compliance Schedule Activity</b>	<b>Due Date</b>	<b>Achieved Date</b>
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	4/2/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2029	

## Water System Facility and Sampling Point Inventory

<b>Water System Facility ID</b>	<b>Water System Facility</b>	<b>Sampling Point ID</b>	<b>Sampling Point Description</b>	<b>Status</b>	<b>Total Coliform Rule</b>	<b>Lead and Copper Rule Tier</b>	<b>Asbestos</b>	<b>Stage WQP 2 DBPR</b>
00600	DISTRIBUTION SYSTEM	010	10 LITTLE BROOK ROAD	A		1	Y	
		011	11 LITTLE BROOK ROAD	A		1	Y	
		015	15 LITTLE BROOK ROAD	A		1	Y	
		016	16 LITTLE BROOK ROAD	A		1	Y	
		022	22 LITTLE BROOK ROAD	A		1	Y	
		023	23 LITTLE BROOK ROAD	A		1	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920041</b>	<b>LITTLE BROOK RD PROPERTY OWNERS ASSN</b>	<b>C</b>	<b>64</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		16					

Towns Served: NEW HARTFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		027	27 LITTLE BROOK ROAD	A		1	Y	
		028	28 LITTLE BROOK ROAD	A		1	Y	
		033	33 LITTLE BROOK ROAD	A		1	Y	
		034	34 LITTLE BROOK ROAD	A		1	Y	
		039	39 LITTLE BROOK ROAD	A		1	Y	
		040	40 LITTLE BROOK ROAD	A		1	Y	
		245	245 TURNBULL ROAD	A		1	Y	
		246	246 TURNBULL ROAD	A		1	Y	
		248	248 TURNBULL ROAD	A		1	Y	
		253	253 TURNBULL ROAD	A		1	Y	
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
31	WELL 1	2	WELL 1	A				
36437	TREATMENT PLANT							
36838	HYDROPNEUMATIC TANK							

## Certified Operator Information

**Water System Facility: TREATMENT PLANT (WSF ID: 36437)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027

## Contact Information

Name			Organization			Job Title			
<b>Ms. Liz Ward</b>			Little Brook Rd Property Owner			Treasurer			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
28 Little Brook Road						New Hartford		CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-231-5670					littlebrookassociation@gmail.com				

Contact Role(s): **Administrative Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0920041</b>	<b>LITTLE BROOK RD PROPERTY OWNERS ASSN</b>	<b>C</b>	<b>64</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		16						
Towns Served: NEW HARTFORD								
Name			Organization			Job Title		
<b>Mr. Rick Dibella</b>			Little Brook Rd Property Owner			President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
16 Little Brook Rd						New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
				860-748-0281	rdb65@hotmail.com			
Contact Role(s): <b>Legal Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920281</b>	<b>WEST HILL LAKE WATER ASSOC.</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			69				

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30	4/1-10/31			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30			
	1/1/27 - 12/31/29	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			69				

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 4/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	4/22/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Total Coliform M&R Violation	7/1/20 - 7/31/20	3	11/12/2021		11/22/2021	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920281</b>	<b>WEST HILL LAKE WATER ASSOC.</b>	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		69					

Towns Served: NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WESTHILL001	#60 DAVIS ROAD	A	Y	1	Y	
		WESTHILL002	#67 DAVIS ROAD	A	Y	1	Y	
		WESTHILL003	#28 CIRCLE DRIVE	A	Y	1	Y	
		WESTHILL004	#88 HELEN HIWAY	A	Y	1	Y	
		WESTHILL005	#9 HILLTOP RD	A	Y	1	Y	
		WESTHILL006	#24 DILLISTON RD	A	Y	1	Y	
00700	ENTRY POINT	3	ENTRY POINT	A				
1935	WELL #2	2	WELL #2	A				
45671	HYDROPNEUMATIC TANK							
556	WELL # 2 TREATMENT STATION							

### Certified Operator Information

Water System Facility: **WELL # 2 TREATMENT STATION (WSF ID: 556)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027

### Contact Information

Name		Organization			Job Title	
<b>West Hill Lake Water Assoc.</b>						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Emergency Contact				Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
877-282-5531						
Contact Role(s): <b>Owner</b>						
Name		Organization			Job Title	
<b>Ms. Jacqueline D'arcy-Lemelin</b>		West Hill Lake Water Assoc.				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
26 Cemetery Road				Canton	CT	06019
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-666-0911					jdarcy111@gmail.com	
Contact Role(s): <b>Administrative Contact, Legal Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			69				

Towns Served: NEW HARTFORD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**