

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **RAW SURFACE WATER ENTRY POINT (WSF ID: 00500)**

Total Alkalinity (1927)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW INFLUENT (1)	12/1/24 - 12/31/24			Complete
	1/1/25 - 1/31/25			Complete
	2/1/25 - 2/28/25			Complete
	3/1/25 - 3/31/25			Complete
	4/1/25 - 4/30/25			Complete
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW INFLUENT (1)	12/1/24 - 12/31/24			Complete
	1/1/25 - 1/31/25			Complete
	2/1/25 - 2/28/25			Complete
	3/1/25 - 3/31/25			Complete
	4/1/25 - 4/30/25			Complete
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW INFLUENT (1)	10/1/24 - 12/31/24			Complete
	1/1/25 - 3/31/25			Complete
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
RAW INFLUENT (1)	1/1/24 - 12/31/24			Complete
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: RAW SURFACE WATER ENTRY POINT (WSF ID: 00500)

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW INFLUENT (1)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RAW INFLUENT (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	40 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Coliform (3100)	40 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NORWALK HOSPITAL (FDW004)	10/1/24 - 12/31/24	11/1-11/30	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
182 WOLFPIT RD (FDW008)	10/1/24 - 12/31/24	11/1-11/30	Complete
	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
HHDC, 34 MIDROCKS DR (FDW017)	10/1/24 - 12/31/24	11/1-11/30	Complete
	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
228 WEST ROCKS ROAD (FDW025)	10/1/24 - 12/31/24	11/1-11/30	Complete
	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	
Lead And Copper (PBCU)		30 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		40 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 1423)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 1 (WSF ID: 1424)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 4 (WSF ID: 1425)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 2 (WSF ID: 1426)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **NORWALK WATER DEPT WELLS (WSF ID: 213)**

Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/22 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **NORWALK WATER DEPT WELLS (WSF ID: 213)**

Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/27		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/19 - 12/31/27		Complete
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLFIELD TP (5)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Water System Facility: NORWALK WATER FILTRATION PLANT (WSF ID: 214)			
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **NORWALK WATER FILTRATION PLANT (WSF ID: 214)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
Net Gross Alpha (4000)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Uranium (4006)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SURFACE TP (5)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Monitoring Requirements

Water System Facility: **WELL 5 (WSF ID: 60276)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **NORWALK WATER DEPT WELLS (WSFID: 213)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2004		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility: **NORWALK WATER DEPT WELLS (WSFID: 213)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 12/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 12/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Water System Facility: **NORWALK WATER FILTRATION PLANT (WSFID: 214)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility: NORWALK WATER FILTRATION PLANT (WSFID: 214)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 12/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 12/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	
	1/1/2025 - 1/31/2025	Y	
	2/1/2025 - 2/28/2025	Y	
	3/1/2025 - 3/31/2025	Y	
	4/1/2025 - 4/30/2025		
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility: **NORWALK WATER FILTRATION PLANT (WSFID: 214)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
WATERSHED SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00500	RAW SURFACE WATER ENTRY POINT	1	RAW INFLUENT	A				
00501	RAW WELLFIELD ENTRY POINT	2	RAW WELL INFLUENT	A				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
		FDW001	1032 SILVERMINE	A	Y			
		FDW002	12 NEW CANAAN AVE	A	Y			
		FDW004	NORWALK HOSPITAL	A	Y		Y	
		FDW005	3 BELDEN AVE	A	Y			
		FDW006	WEST ROCKS PUMP STA	A	Y			
		FDW007	238 W ROCKS RD/BAYNE	A	Y		Y	
		FDW008	182 WOLFPIT RD	A	Y		Y	
		FDW010	51 STEVENS ST	I			2	
		FDW011	56 VAN ZANT ST	A	Y			
		FDW012	WESTPORT AVE FIREHS	A	Y			
		FDW013	76 WEST ROCKS RD	A	Y			
		FDW014	531 WESTPORT AVE	A	Y			
		FDW015	125 EAST AVE	A	Y			
		FDW016	GRANDVIEW FINEST	I				
		FDW017	HHDC, 34 MIDROCKS DR	A	Y		N	Y
		FDW018	YMCA, 370 WEST AVE	I	Y		N	
		FDW019	CES 10 KNOWALOT LN	I	Y		N	
		FDW020	B OF A, 93 WINFIELD	I	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FDW021	208 NEWTOWN AVE	A	Y	N		
		FDW022	MARRIOTT, 474 MAIN	A	Y			
		FDW023	515 WEST AVE	A	Y			
		FDW024	149 WESTORT AVE	A	Y			
		FDW025	228 WEST ROCKS ROAD	A	Y			Y
		FDW026	2 FORT POINT ROAD	A	Y			
		FDW027	34 GRANDVIEW AVE EFF	A	Y			
		FDW028	50 WILTON AVE	A	Y			
		FDW029	230 EAST AVE	A	Y			
		FDW102	48 GRUMMAN AVE	I			2	
		FDW103	17 MARK DR	I			2	
		FDW105	32 CANNON ST	I			2	
		FDW112	2 BRIDGE ST	I			2	
		FDW114	5 CLOVERLY CI	I			2	
		FDW117	20 EVERSLEY AVE	I			2	
		FDW118	68 EAST ROCKS RD	I			2	
		FDW119	21 ROME ST	I			2	
		FDW121	9 BLACKBERRY LN	I			2	
		FDW122	5 GLENDENNING ST	I			2	
		FDW123	103 DRY HILL RD	I			2	
		FDW126	73 NEWTOWN AVE	I			2	
		FDW142	22 CRICKLEWOOD LN	I			2	
		FDW145	88 WEST ROCKS RD	I			2	
		FDW146	9 BOBWHITE DR	I			2	
		FDW147	18 SHERWOOD ST	I			2	
		FDW149	2 OX YOKE LN	I			2	
		FDW150	5 FAIRVIEW AVE	I			2	
		FDW152	7 1/2 FAIRVIEW AVE	I			2	
		FDW157	12 POPLAR ST	I			2	
		FDW158	48 EMERSON ST	I			2	
		FDW160	3 STANLEY ST	I			2	
		FDW169	5 GRAND ST	I			2	
		FDW170	5 GRAND ST	I			2	
		FDW171	9 PLYMOUTH AVE	I			2	
		FDW172	129 WINFIELD ST	I			2	
		FDW175	19 ALGONQUIN RD	I			2	
		FDW176	38 ADAMS AVE	I			2	
		FDW177	1 CANNON ST	I			2	
		FDW178	27 AIKEN ST	I			2	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FDW179	24 CATHERINE ST	I		2		
		FDW180	11 BLUE MOUNTAIN RD	I		2		
		FDW181	36 MOHAWK DR	I		2		
		FDW183	19 HAYES AVE	I		2		
		FDW184	17 HAYES AVE	I		2		
		FDW185	736 VALLEY, N CANAAN	I		2		
		FDW188	6 EAST AVE	I		2		
		FDW189	8 POPLAR ST	I		2		
		FDW190	143 NEWTOWN AVE	I		2		
		FDW301	20 HLLNDL MANOR-ASB	I				
		FDW302	14 HORTON ST	I		2		
		FDW400	5 ALVIN DRIVE	A			Y	
		FDW401	20 HILLANDALE MANOR	A			Y	
		FDW402	40 KING STREET	A			Y	
		FDW403	41 MURRAY ST	A			Y	
		FDW404	22 THEODORE LANE	A			Y	
		FDW500	4 EMERSON ST	I		1		
		FDW501	16 EMERSON ST	A		1		
		FDW502	19 EMERSON ST	A		1		
		FDW503	33 EMERSON ST	A		1		
		FDW504	25 MAGNOLIA AVE	A		1		
		FDW505	26 MAGNOLIA AVE	A		1		
		FDW506	31 MAGNOLIA AVE	A		1		
		FDW507	33 MAGNOLIA AVE	A		1		
		FDW508	35 MAGNOLIA AVE	A		1		
		FDW509	15 MAGNOLIA AVE	A		1		
		FDW510	20 OHIO AVE	A		1		
		FDW511	23 OHIO AVE	I		1		
		FDW512	29 OHIO AVE	A		1		
		FDW513	16 PLYMOUTH AVE	A		1		
		FDW514	17 PLYMOUTH AVE	A		1		
		FDW515	22 PLYMOUTH AVE	A		1		
		FDW516	31 PLYMOUTH AVE	A		1		
		FDW517	56 WINFIELD ST	A		1		
		FDW518	11 HAYES AVE	A		1		
		FDW519	38 RAYMOND TERR	A		1		
		FDW520	53 RAYMOND TERR	A		1		
		FDW521	8 RAYMOND TERR	A		1		
		FDW522	32 MYRTLE ST	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FDW523	7 MYRTLE ST	A		1		
		FDW524	25 RUSSELL ST	A		1		
		FDW525	59 RUSSELL ST	I		1		
		FDW526	11 AMUNDSEN ST	A		1		
		FDW527	21 AMUNDSEN ST	A		1		
		FDW528	27 AMUNDSEN ST	A		1		
		FDW529	10 EDLIE AVE	A		1		
		FDW530	19 EMERSON ST	I		1		
		FDW531	4 EMERSON ST	A		1		
		FDW532	1 BRIDGE ST	A		1		
		FDW533	198 EAST AVE	I		1		
		FDW534	29 HAYES ST	A		1		
		FDW535	6 HAYES ST	A		1		
		FDW536	30 AIKEN ST	A		1		
		FDW537	5 HUDSON ST	A		1		
		FDW538	31 CAMP ST	A		1		
		FDW539	25 HARRIET ST	A		1		
		FDW540	39 HARRIET ST	A		1		
		FDW541	24 PLYMOUTH AVE	A		1		
		FDW542	3 PLYMOUTH AVE	A		1		
		FDW543	16 LOUNDSBURY AVE	A		1		
		FDW544	23 LOUNDSBURY AVE	A		1		
		FDW545	5 LOUNDSBURY AVE	A		1		
		FDW546	42 LAKEVIEW DR	A		1		
		FDW547	5 LAKEVIEW DR	A		1		
		FDW548	14 MERRILL RD	A		1		
		FDW549	4 MERRILL RD	A		1		
		FDW550	7 MERRILL RD	A		1		
		FDW551	15 MILLS ST	A		1		
		FDW552	21 MILLS ST	A		1		
		FDW553	17 MORGAN AVE	A		1		
		FDW554	22 MORGAN AVE	A		1		
		FDW555	6 MORGAN AVE	A		1		
		FDW556	45 GEORGE AVE	A		1		
		FDW557	71 GEORGE AVE	A		1		
		FDW558	25 FAIRVIEW AVE	A		1		
		FDW559	45 OHIO AVE	A		1		
		FDW560	5 OHIO AVE	A		1		
		FDW561	7 DISESA CT	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FDW562	8 DISESA CT	A		1		
		FDW563	15 FAIRFIELD TERRACE	A		1		
		FDW564	22 1/2 FRANCE ST	I		1		
		FDW565	5 DELAWARE AVE	A		1		
		FDW566	7 WILLOW ST	A		1		
		FDW567	7 HUDSON ST	A		1		
		FDW568	2 HUDSON ST	A		1		
		FDW569	21 HARRIET ST	A		1		
		FDW570	44 EAST AVE	A		1		
		FDW571	160 EAST AVE	I		1		
		FDW572	29 PLYMOUTH AVE	A		1		
		FDW573	23 OHIO AVE	A		1		
		FDW574	8 MORGAN AVE	A		1		
		FDW575	14 UNION AVE	A		1		
		FDW576	12 MOTT AVE	I		1		
		FDW577	13 BYINGTON PL	I		1		
		FDW578	1 PLATT ST	A		1		
		FDW579	8 PLEASANT ST	A		1		
		FDW580	10 PLEASANT ST	A		1		
		FDW581	15 PLEASANT ST	A		1		
		FDW582	17 PLEASANT ST	A		1		
		FDW583	13 RAYMOND TERR	A		1		
		FDW584	40 RAYMOND TERR	A		1		
		FDW585	2 MYRTLE STREET	A		1		
		FDW586	9 MYRTLE STREET	A		1		
		FDW587	14 MYRTLE STREET	A		1		
		FDW588	27 MYRTLE STREET	A		1		
		FDW589	59 RUSSELL ST	A		1		
		FDW590	61 RUSSELL ST	A		1		
		FDW591	49 RUSSELL ST	A		1		
		FDW592	7 AMUNDSEN ST	A		1		
		FDW593	515 WEST AVE	I	Y			
		FDW594	18 PLEASANT ST	A		1		
		FDW595	5 PLATT ST	A		1		
		FDW596	8 REYNOLDS ST	A		1		
		FDW597	20 BUCKINGHAM PL	A		1		
		FDW598	1 BUCKINGHAM PL	A		1		
		FDW599	24 BUCKINGHAM PL	A		1		
		FDW600	4 DELAWARE AVE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	

Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		FDW601	6 EAST AVE	A		1		
		FDW602	22 EMERSON ST	A		1		
		FDW603	27 HARRIET ST	A		1		
		FDW604	18 HUDSON ST	A		1		
		FDW605	1 MILLS ST	A		1		
		FDW606	13 MORGAN AVE	A		1		
		FDW607	26 MORGAN AVE	A		1		
		FDW608	4 MORGAN AVE	A		1		
		FDW609	35 PARKHILL AVE	A		1		
		FDW610	45 RAYMOND TERR	A		1		
		FDW611	70 SILVERMINE AVE	A		1		
		FDW612	132 WINFIELD ST	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
1423	WELL 3	2	WELL 3	A				
1424	WELL 1	2	WELL 1	A				
1425	WELL 4	2	WELL 4	A				
1426	WELL 2	2	WELL 2	A				
213	NORWALK WATER DEPT WELLS	5	EP - WELLFIELD TP	A				
213CW	KELLOGG-DEERING CLEARWELL							
214	NORWALK WATER FILTRATION PLANT	5	EP - SURFACE TP	A				
214CW	FILTRATION PLANT CLEARWELL							
2175	GRUPES RESERVOIR	1	GRUPES RESERVOIR	A				
2176	JOHN D. MILNE RESERVOIR	1	JOHN D. MILNE RES	A				
2177	BROWNS RESERVOIR	1	BROWNS RESERVOIR	A				
2178	SCOTTS RESERVOIR	1	SCOTTS RESERVOIR	A				
30072	GRUPES RESERVOIR							
48276	JOHN D. MILNE RESERVOIR							
49949	WEST ROCKS PUMP STATION							
50043	INTERCONNECTION - CT0150011 - ROUTE 7							
50059	INTERCONNECTION - CT0150011 - MURRAY							
50698	BAYNE ST TANK							
51689	SPRING HILL TANK							
51691	FILBERT ST TANK							
51693	WEST ROCKS TANK							
51699	DEERING PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						11,042	
Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
51701	SPRING HILL PUMP STATION							
51703	VALLEY RD PUMP STATION							
51705	COMSTOCK HILL PUMP STATION							
58604	SILVERMINE CROSSING PUMP STATION							
59208	FILTER PLANT PUMP STATION							
59386	SPRING HILL ELEVATED TANK							
60276	WELL 5	2	WELL 5	A				
61393	INTERCONNECTION - CT0150011 - SAUGATUCK							
61396	INTERCONNECTION - CT0150011 - WINFIELD							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM				Certification Expiration
Operator Name	Operator Type	Certification(s)		
UKERS III, DONALD F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2027	
MCBENNETT, JR., PATRICK G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2025	

Water System Facility: NORWALK WATER DEPT WELLS (WSF ID: 213)

Facility Classification: CLASS 2 TREATMENT PLANT				Certification Expiration
Operator Name	Operator Type	Certification(s)		
FERNANDEZ, SERGIO	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027	
STAACK, CHARLES W.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2024	

Water System Facility: NORWALK WATER FILTRATION PLANT (WSF ID: 214)

Facility Classification: CLASS 4 TREATMENT PLANT				Certification Expiration
Operator Name	Operator Type	Certification(s)		
FERNANDEZ, SERGIO	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027	
STAACK, CHARLES W.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2024	
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027	

Contact Information

Name		Organization			Job Title			
First Taxing District								
Mailing Address Line One				Mailing Address Line Two		City	State	Zip Code
12 New Canaan Ave						Norwalk	CT	06851
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
Contact Role(s):		Owner						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1030011	NORWALK FIRST TAXING DISTRICT	C	40,256	L	SW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
						11,042		
Towns Served: NEW CANAAN, NORWALK, WESTPORT, WILTON								
Name		Organization			Job Title			
Ms. Eleanor M. Militana		First District Water Dept.			General Manager			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
12 New Canaan Avenue			PO Box 27			Norwalk	CT	06852
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-847-7387		203-846-3482		203-247-2225	emilitana@firstdistrictwater.org			
Contact Role(s): Administrative Contact, Legal Contact, Owner								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
Asbestos (1094)		1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29			
Total Coliform (3100)		50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
7 COVE AVE (22)	10/1/24 - 12/31/24	11/1-11/30	Complete	
	1/1/25 - 3/31/25	2/1-2/28	Complete	
	4/1/25 - 6/30/25	5/1-5/31		
	7/1/25 - 9/30/25	8/1-8/31		
	10/1/25 - 12/31/25	11/1-11/30		
119 ROWAYTON AVE (26)	10/1/24 - 12/31/24	11/1-11/30	Complete	
	1/1/25 - 3/31/25	2/1-2/28	Complete	
	4/1/25 - 6/30/25	5/1-5/31		
	7/1/25 - 9/30/25	8/1-8/31		
	10/1/25 - 12/31/25	11/1-11/30		
800 CONNECTICUT AVE (32)	10/1/24 - 12/31/24	11/1-11/30	Complete	
	1/1/25 - 3/31/25	2/1-2/28	Complete	
	4/1/25 - 6/30/25	5/1-5/31		
	7/1/25 - 9/30/25	8/1-8/31		
	10/1/25 - 12/31/25	11/1-11/30		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
4 FELIX LN SS (39)	10/1/24 - 12/31/24	11/1-11/30	Complete
	1/1/25 - 3/31/25	2/1-2/28	Complete
	4/1/25 - 6/30/25	5/1-5/31	
	7/1/25 - 9/30/25	8/1-8/31	
	10/1/25 - 12/31/25	11/1-11/30	

Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

Physical Parameters (PPS)		50 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Uranium (4006)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Combined Radium-226/228 (4010)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **SECOND TAXING DISTRICT FILTRATION PLANT (WSF ID: 216)**

Total Organic Carbon (2920) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE- SECOND DISTRICT (5)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **CITY LAKE RESERVOIR (WSF ID: 2179)**

Total Alkalinity (1927) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CITY LAKE RESERVOIR (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Monitoring Requirements

Water System Facility: **CITY LAKE RESERVOIR (WSF ID: 2179)**

Total Alkalinity (1927)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CITY LAKE RESERVOIR (1)	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CITY LAKE RESERVOIR (1)	10/1/24 - 12/31/24		Complete	
	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
CITY LAKE RESERVOIR (1)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Monitoring Requirements

Water System Facility: **CITY LAKE RESERVOIR (WSF ID: 2179)**

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CITY LAKE RESERVOIR (1)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CITY LAKE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily	
Start Date: 6/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		
		1/1/2025 - 1/31/2025		
		2/1/2025 - 2/28/2025		
		3/1/2025 - 3/31/2025		
		4/1/2025 - 4/30/2025		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 6/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024	Y	
		1/1/2025 - 1/31/2025	Y	
		2/1/2025 - 2/28/2025	Y	
		3/1/2025 - 3/31/2025	Y	
		4/1/2025 - 4/30/2025		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily	
Start Date: 9/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		
		1/1/2025 - 1/31/2025		
		2/1/2025 - 2/28/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: SECOND TAXING DISTRICT FILTRATION PLANT (WSFID: 216)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility: **SECOND TAXING DISTRICT FILTRATION PLANT (WSFID: 216)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 9/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
WATERSHED SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00500	RAW SURFACE WATER ENTRY POINT	1	RAW ENTRY POINT	A			
00600	DISTRIBUTION SYSTEM	001	2 AUBURN ST	A		1	
		002	15 AVE C	A		1	
		003	20 AVE D	A		1	
		004	23 AVE D	A		1	
		005	5 CLIFFORD ST	A		1	
		006	9 CLIFFORD ST	A		1	
		009	21 COSSITT RD	A		1	
		010	18 CRAW AV	A		1	
		011	11 CROOKED TRAIL RD	A		1	
		012	6 DEVIL'S GARDEN RD	A		1	
		013	5 EVERGREEN TER	A		1	
		014	18 HARSTROM PL	A		1	
		016	125 KEELER AVE	A		1	
		017	9 LEDGE RD	I		1	
		018	7 OAK LEDGE CIRCLE	A		1	
		019	9 OAK LEDGE CR	A		1	
		020	18 OAK LEDGE CR	A		1	
		021	19 OAK LEDGE CR	A		1	
		022	25 POINT RD	A		1	
		023	144 SILVERMINE AVE	A		1	
		024	3 POND RIDGE RD	A		1	
		025	4 POND RIDGE LN	A		1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		026	5 POND RIDGE LN	A		1		
		028	7 POND RIDGE LN	A		1		
		029	8 POND RIDGE RD	A		1		
		030	9 POND RIDGE LN	A		1		
		031	167 OLD KING'S HWY	I		1		
		033	14 RICHMOND HILL RD	A		1		
		034	239 ROWAYTON AVE	A		1		
		035	369 ROWAYTON AV	A		1		
		036	373 ROWAYTON AV	A		1		
		037	56 SAMMIS ST	I		1		
		038	8 SENGAR RD	A		1		
		039	144 SILVERMINE AV	A		1		
		040	9 TUTHILL AV	A		1		
		041	74 WILSON AVE	A		1		
		042	36 WILSON AVE	A		1		
		043	29 WITCH LN	A		1		
		044	14 WOODBINE ST	A		1		
		045	35 BENEDICT ST	A		1		
		046	37 BENEDICT ST	A		1		
		047	6 CANA CT	A		1		
		048	2 FRENCH FARM RD	A		1		
		049	3 FRENCH FARM RD	A		1		
		050	4 FRENCH FARM RD	A		1		
		051	5 FRENCH FARM RD	A		1		
		052	3 LESLIE LN	A		1		
		053	6 LESLIE LN	A		1		
		054	7 LESLIE LN	A		1		
		055	10 LESLIE LN	A		1		
		056	11 NEW CANAAN CT	A		1		
		057	22 NEW CANAAN CT	A		1		
		058	33 NEW CANAAN CT	A		1		
		059	44 NEW CANAAN CT	A		1		
		060	44 NEW CANAAN CT	I		1		
		061	9 NURSERY CT	A		1		
		062	10 NURSERY CT	A		1		
		063	1 NURSERY CT	A		1		
		064	117 PONUS AVE	A		1		
		065	18 RED OAK LN	A		1		
		066	4 STYLES LN	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		067	36 WITCH LN	A		1		
		075	22 QUINTARD AVE	A		1		
		076	14 AVENUE B	A		1		
		077	357 NEW CANAAN RD	A		1		
		078	67 OLD KINGS HWY	A		1		
		079	83 OLD KINGS HWY	A		1		
		080	13 LORDS HILL WAY	A		1		
		081	4 TELVA RD	A		1		
		082	3 TELVA RD	A		1		
		083	11 CREST RD	A		1		
		084	24 TORY PL	A		1		
		085	16 TORY PL	A		1		
		086	16 MUSKET RIDGE RD	A		1		
		087	34 MUSKET RIDGE RD	A		1		
		088	60 BORGLUM RD	A		1		
		089	66 BORGLUM RD	A		1		
		18	34 TORY PL	A	Y			
		19	106 OLD KING'S HWY	I	Y			
		20	37 MUSKET RIDGE RD	I	Y			
		21	60 GREGORY BLVD	A	Y			
		22	7 COVE AVE	A	Y			Y
		23	164 WATER ST	A	Y			
		24	149 WOODWARD AVE	I	Y			
		25	356 ELY AVE	A	Y			
		25X	DUKE PL	I	Y			
		26	119 ROWAYTON AVE	A	Y			Y
		27	9 ARNOLD LANE	I	Y			
		27X	7 ARNOLD LN	I	Y			
		28	382 HIGHLAND AVE	I	Y			
		29	228 FILLow ST	I	Y			
		30	188 RICHARDS AVE	I	Y			
		31	102 1/2 GILLIES LANE	A	Y			
		32	800 CONNECTICUT AVE	A	Y			Y
		33	121 CONNECTICUT AVE	I	Y			
		34	51 SCRIBNER AVE	A	Y			
		35	10 WASHINGTON ST	A	Y			
		36	5 BARTLETT AVE	A	Y			
		37	260 NEW CANAAN AVE	I	Y			Y
		38	1 STATE ST	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		39	4 FELIX LN SS	A	Y			Y
		4	GENERIC DISTRIBUTION	A	Y			
		68	151 WOODWARD AVE	A	Y			
		69	24 HILLWOOD PL	A	Y			
		70	20 OLD BOSTON, WILTN	I	Y			
		71	300 ROWAYTON AVE	A	Y			
		72	116 CONNECTICUT AVE	A	Y			
		73	360 CONNECTICUT AVE	A	Y			
		74	33 SEIR HILL RD	A	Y			
		75	167 ROWAYTON AVE	I	Y			
		76	3 FLOWER LN SS	A	Y			
		77	181 RICHARDS SS	A	Y			
		78	114 1/2 PONUS AVE	A	Y			
		DN	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UP	GENERATED BY BATCH	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
216	SECOND TAXING DISTRICT FILTRATION PLANT	5	CFE- SECOND DISTRICT	A				
2179	CITY LAKE RESERVOIR	1	CITY LAKE RESERVOIR	A				
2180	NEW CANAAN RESERVOIR	1	NEW CANAAN RES.	A				
2186	ROCK LAKE RESERVOIR	1	RESERVOIR	A				
2187	POPE'S POND RESERVOIR	1	RESERVOIR	A				
2188	CRYSTAL LAKE RESERVOIR	1	RESERVOIR	A				
2189	MIDDLEBROOK DIVERSION	1	RESERVOIR	A				
30073	CITY LAKE GATEHOUSE							
44903	INTERCONNECTION - CT0350011 - FLAX HILL							
50064	INTERCONNECTION - CT0900011 - NEW CANAAN							
53009	FILTRATION PLANT CLEARWELL							
53011	WILTON PUMP STATION							
53013	WITCH LANE STORAGE TANK							
53015	BARTLETT AVENUE PUMP STATION							
53017	PONUS AVENUE PUMP STATION							
53019	MICHAEL STREET STORAGE TANK							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						9,682	

Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
53021	SUMMIT AVENUE STORAGE TANK							
53023	PRICE STREET STORAGE TANK							
53025	STEVENS HILL STORAGE TANK							
53027	FLOWER LANE STORAGE TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
MORAN, PATRICK C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
ANDRIOPOULOS, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024

Water System Facility: **SECOND TAXING DISTRICT FILTRATION PLANT (WSF ID: 216)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DESSEREAUX, DANA	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
CHAREST, SAMUEL B	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2026
SCHOEN, ALEXANDER C	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026

Contact Information

Name	Organization	Job Title
Mr. Paul Yatcko	South Norwalk Electric & Water	General Manager

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code	
1 State St		Norwalk	CT	06854	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-866-4446		203-899-7491			pyatcko@snew.org

Contact Role(s): **Legal Contact**

Name	Organization	Job Title
Mr. Alan E. Huth	Snew	Owner

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code	
1 State Street	P.O. Box 400	Norwalk	CT	06856	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-866-3366	210				ahuth@snew.org

Contact Role(s): **Owner**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1030021	SOUTH NORWALK ELECTRIC & WATER	C	42,000	L	SW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
						9,682		
Towns Served: DARIEN, NEW CANAAN, NORWALK, WILTON								
Name			Organization			Job Title		
Ms. Elisabeth O. Burns			Snew			Dir. of Water Op		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
164 Old Boston Road						Wilton	CT	06897
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-866-3366	250				eburns@SNEW.org			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule