

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					250		

Towns Served: SPRAGUE

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
1 MAIN STREET (2012)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31			
	1/1/26 - 12/31/26	7/1-7/31			
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
36 WALL STREET (2007)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31			
	1/1/26 - 12/31/26	7/1-7/31			
Total Coliform (3100)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
Lead And Copper (PBCU)		10 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
Physical Parameters (PPS)		2 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					250		

Towns Served: SPRAGUE

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: ENTRY POINT - WELLS #1, #2A & #3 (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					250		

Towns Served: SPRAGUE

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS #1, #2A & #3 (WSF ID: 00700)

Strontium-90 (4174)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Organic Chemicals (VOCS)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
Water System Facility: ENTRY POINT - WELLS #4 & #5 (WSF ID: 00701)					
Net Gross Alpha (4000)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 4 & 5 (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Uranium (4006)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 4 & 5 (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Combined Radium-226/228 (4010)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
EP - WELLS 4 & 5 (3)	10/1/24 - 12/31/24		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						250	

Towns Served: SPRAGUE

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS #4 & #5 (WSF ID: 00701)**

Combined Radium-226/228 (4010)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 4 & 5 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						250	

Towns Served: SPRAGUE

Monitoring Requirements

Water System Facility: **WELL #1 (WSF ID: 1711)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #2A (WSF ID: 1712)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #3 (WSF ID: 1713)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 4 (WSF ID: 1949)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 5 (WSF ID: 1950)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						250	

Towns Served: SPRAGUE

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS #1, #2A & #3 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Water System Facility: ENTRY POINT - WELLS #4 & #5 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2008			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						250	

Towns Served: SPRAGUE

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	1001	WELL HOUSE	P	Y			
		1002	101 HIGH STREET	P	Y			
		1003	WWTF	P	Y			
		2003	WWTF	P		3		
		2004	73 RIVER STREET	P		3		
		2005	FIRE HOUSE	P		3		
		2006	SOUTH PUMP STATION	P		3		
		2007	36 WALL STREET	A		3		Y
		2008	197 HIGH STREET	P		3		
		2009	24 WEST MAIN STREET	P		3		
		2010	101 HIGH STREET	P		3		
		2011	TEST HOUSE	P		3		
		2012	1 MAIN STREET	A		3		Y
		2013	POST OFFICE	P		3		
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELLS #1, #2A & #3	3	ENTRY POINT	A				
00701	ENTRY POINT - WELLS #4 & #5	3	EP - WELLS 4 & 5	A				
1711	WELL #1	2	WELL #1	A				
1712	WELL #2A	2	WELL #2	A				
1713	WELL #3	2	WELL #3	A				
1949	WELL 4	2	WELL 4	A				
1950	WELL 5	2	WELL 5	A				
385	WELL 1-3 TREATMENT PLANT & PUMP HOUSE							
55141	WELLS #4 & #5 TREATMENT STATION							
55148	150,000 GAL STANDPIPE							
55150	85,000 GAL STANDPIPE							
62308	SMALL STORAGE TANK							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1330021	SPRAGUE WATER & SEWER AUTHORITY	C	1,058	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						250	

Towns Served: SPRAGUE

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
HASTINGS, TODD R.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Water System Facility: WELL 1-3 TREATMENT PLANT & PUMP HOUSE (WSF ID: 385)

Facility Classification: CLASS 2 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
HASTINGS, TODD R.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Water System Facility: WELLS #4 & #5 TREATMENT STATION (WSF ID: 55141)

Facility Classification: CLASS 1 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
HASTINGS, TODD R.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization			Job Title	
Mr. Todd R. Hastings		Sprague Water & Sewer Auth.			Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
One Main Street		P.O. Box 746		Baltic	CT	06330
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-822-3005				860-822-3000	spraguwatersewer@ctsprague.org	

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title	
Mr. Dennison Allen		Sprague Water & Sewer			Chairman	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
One Main Street		P.O. Box 746		Baltic	CT	06330
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-822-3000	225	860-822-3016	860-884-3588	860-822-3005	spraguwatersewer@ctsprague.org	

Contact Role(s): **Legal Contact**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.