

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	<b>C</b>	<b>124</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
8 KNOLLCREST DR SS (01906)	1/1/24 - 12/31/24	8/10-8/16	Complete		
	1/1/25 - 12/31/25	8/10-8/16			
	1/1/26 - 12/31/26	8/10-8/16			
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	C	124	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per six years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		
	1/1/26 - 12/31/31		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: **WELL 1 (WSF ID: 579)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 3 (WSF ID: 580)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	C	124	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 580)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 2 (WSF ID: 643)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 4 (WSF ID: 644)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 12/1/2012	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	<b>C</b>	<b>124</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		31					

Towns Served: BROOKFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	01906	8 KNOLLCREST DR SS	A	Y			Y
		4	DISTRIBUTION SYSTEM	A	Y			
		BUTTER002	4 KNOLLCREST	A		3		
		BUTTER003	9 KNOLLCREST	A		3		
		BUTTER004	1 BLUEBERRY	A		3		
		BUTTER005	12 KNOLLCREST	A		3		
		BUTTER006	36 KNOLLCREST	A		3		
		BUTTER007	2 KNOLLCREST	A	Y	3		
		BUTTER008	6 KNOLLCREST	A	Y	3		
		BUTTER009	7 KNOLLCREST	A	Y	3		
		BUTTER010	8 KNOLLCREST	A	Y	3		
		BUTTER011	10 KNOLLCREST	A	Y	3		
		BUTTER012	11 KNOLLCREST	A	Y	3		
		BUTTER013	13 KNOLLCREST	A	Y	3		
		BUTTER014	14 KNOLLCREST	A		3		
		BUTTER015	15 KNOLLCREST	A	Y	3		
		BUTTER017	17 KNOLLCREST	A	Y	3		
		BUTTER018	20 KNOLLCREST	A	Y	3		
		BUTTER020	22 KNOLLCREST	A	Y	3		
		BUTTER022	24 KNOLLCREST	A	Y	3		
		BUTTER023	25 KNOLLCREST	A	Y	3		
		BUTTER026	30 KNOLLCREST	A	Y	3		
		BUTTER027	32 KNOLLCREST	A	Y	3		
		BUTTER028	34 KNOLLCREST	A	Y	3		
		BUTTER029	38 KNOLLCREST	A	Y	3		
		BUTTER030	40 KNOLLCREST	A	Y	3		
		BUTTER031	3 BLUEBERRY	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6899	16 KNOLLCREST	A		3		
		PB6900	23 KNOLLCREST	A	Y	3		
		PB6901	28 KNOLLCREST	A	Y	3		
		PB6902	27 KNOLLCREST	A		3		
		PB6903	26 KNOLLCREST	A		3		
		PB6904	21 KNOLLCREST	A		3		
		PB8512	10 KNOLLCREST DR	A		3		
		PB8598	11 KNOLLCREST DR	A		3		
		PB8599	14 KNOLLCREST DR.	A		3		
		PB8600	17 KNOLLCREST DR	A		3		
		PB8601	24 KNOLLCREST DR.	A		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	<b>C</b>	<b>124</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		31					

Towns Served: BROOKFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB8602	25 KNOLLCREST DR	A		3		
		PB8603	30 KNOLLCREST DR	A		3		
		PB8604	36 KNOLLCREST DR	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
49224	STORAGE TANK							
49228	PUMP HOUSE							
579	WELL 1	2	WELL 1	A				
580	WELL 3	2	WELL 3	A				
58204	BUTTERNUT TREATMENT PLANT							
643	WELL 2	2	WELL 2	A				
644	WELL 4	2	WELL 4	A				

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:**

Operator Name	Operator Type	Certification(s)	Certification Expiration
O'SHEA, DANIEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
LAGO, ANTHONY V.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2025
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026

**Water System Facility: BUTTERNUT TREATMENT PLANT (WSF ID: 58204)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

### Contact Information

Name		Organization			Job Title	
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct			Vp-Supply & Utility	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Aquarion Water Company of Ct		505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180021</b>	<b>AQUARION-BUTTERNUT</b>	<b>C</b>	<b>124</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		31					

Towns Served: BROOKFIELD

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	1,315	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31			
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
55 LONGVIEW DR (CSTD070)	1/1/24 - 12/31/24	7/1-7/31	Complete	
	1/1/25 - 12/31/25	7/1-7/31		
	1/1/26 - 12/31/26	7/1-7/31		
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
24 S LAKESHORE DR (CSTD053)	1/1/24 - 12/31/24	7/1-7/31	Complete	
	1/1/25 - 12/31/25	7/1-7/31		
	1/1/26 - 12/31/26	7/1-7/31		
<b>Total Coliform (3100)</b>		<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete	
	1/1/25 - 12/31/27	6/1-9/30		
<b>Physical Parameters (PPS)</b>		<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	C	1,315	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Physical Parameters (PPS)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	1,315	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Monitoring Requirements

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Water System Facility: WELL 1 (WSF ID: 1642)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	12/1/24 - 12/31/24		Out of Service
	1/1/25 - 1/31/25		Out of Service
	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

**Water System Facility: WELL 6 (WSF ID: 1643)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

**Water System Facility: WELL 7 (WSF ID: 1644)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 7 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	<b>1,315</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Monitoring Requirements

Water System Facility: **WELL 7 (WSF ID: 1644)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 8 (WSF ID: 1645)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 8 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 9 (WSF ID: 1646)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 9 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	<b>1,315</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

## Monitoring Requirements

Water System Facility: **WELL 9 (WSF ID: 1646)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 2 (WSF ID: 556)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 3 (WSF ID: 557)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	12/1/24 - 12/31/24		Out of Service
	1/1/25 - 1/31/25		Out of Service
	2/1/25 - 2/28/25		Out of Service
	3/1/25 - 3/31/25		Out of Service
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

--

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	C	1,315	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

## Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 12/1/2011	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CSTD001	21 N LAKESHORE DR	A	Y			
		CSTD002	22 N LAKESHORE DR	A	Y			
		CSTD003	18 N LAKESHORE DR	A	Y			
		CSTD004	23 N LAKESHORE DR	A	Y			
		CSTD005	24 N LAKESHORE DR	A	Y			
		CSTD006	25 N LAKESHORE DR	A	Y			
		CSTD007	28 N LAKESHORE DR	A	Y			
		CSTD008	32 N LAKESHORE DR	A	Y			
		CSTD009	34 N LAKESHORE DR	A	Y			
		CSTD010	41 N LAKESHORE DR	A	Y			
		CSTD011	37 N LAKESHORE DR	A	Y			
		CSTD012	7 SKYLINE DR	A	Y			
		CSTD013	27 SKYLINE DR	A	Y			
		CSTD014	40 SKYLINE DR	A	Y			
		CSTD015	34 SKYLINE DR	A	Y			
		CSTD016	39 SKYLINE DR	A	Y			
		CSTD017	26 SKYLINE DR	A	Y			
		CSTD018	28 SKYLINE DR	A	Y			
		CSTD019	29 SKYLINE DR	A	Y			
		CSTD020	31 SKYLINE DR	A	Y			
		CSTD021	33 SKYLINE DR	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	1,315	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CSTD022	50 SKYLINE DR	A	Y			
		CSTD023	59 SKYLINE DR	A	Y			
		CSTD025	61 SKYLINE DR	A	Y	3		
		CSTD025 - 6	GENERATED BY BATCH	A	Y			
		CSTD026	100 N LAKESHORE DR	A	Y			
		CSTD027	73 N LAKESHORE DR	A	Y			
		CSTD028	89 CLEARVIEW DR	A	Y			
		CSTD029	88 N LAKESHORE DR	A	Y			
		CSTD030	89 N LAKESHORE DR	A	Y			
		CSTD031	97 N LAKESHORE DR	A	Y			
		CSTD032	99 N LAKESHORE DR	A	Y			
		CSTD033	93 CLEARVIEW DR	A	Y			
		CSTD034	95 CLEARVIEW DR	A	Y			
		CSTD035	97 CLEARVIEW DR	A	Y			
		CSTD036	87 CLEARVIEW DR	A	Y			
		CSTD037	72 N LAKESHORE DR	A	Y	3		
		CSTD037 - 7	GENERATED BY BATCH	A	Y			
		CSTD038	133 N LAKESHORE DR	A	Y			
		CSTD039	135 N LAKESHORE DR	A	Y			
		CSTD040	137 N LAKESHORE DR	A	Y			
		CSTD041	139 N LAKESHORE DR	A	Y			
		CSTD042	160 N LAKESHORE DR	A	Y			
		CSTD043	153 N LAKESHORE DR	A	Y			
		CSTD044	30 TWILIGHT LA	A	Y			
		CSTD045	35 TWILIGHT LA	A	Y			
		CSTD046	24 TWILIGHT LA	A	Y			
		CSTD047	80 S LAKESHORE DR	A	Y	3		
		CSTD048	8 DOGWOOD LA	A	Y			
		CSTD049	1 DOGWOOD LA	A	Y			
		CSTD050	3 DOGWOOD LA	A	Y			
		CSTD051	5 DOGWOOD LA	A	Y			
		CSTD052	20 S LAKESHORE DR	A	Y			
		CSTD053	24 S LAKESHORE DR	A	Y			Y
		CSTD054	26 S LAKESHORE DR	A	Y			
		CSTD055	28 S LAKESHORE DR	A	Y			
		CSTD056	52 S LAKESHORE DR	A	Y			
		CSTD057	54 S LAKESHORE DR	A	Y	1		
		CSTD057 - 5	GENERATED BY BATCH	A	Y			
		CSTD058	56 S LAKESHORE DR	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	1,315	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CSTD059	58 S LAKESHORE DR	A	Y			
		CSTD060	43 S LAKESHORE DR	A	Y			
		CSTD061	57 S LAKESHORE DR	A	Y			
		CSTD062	60 S LAKESHORE DR	A	Y			
		CSTD063	73 S LAKESHORE DR	A	Y			
		CSTD064	76 S LAKESHORE DR	A	Y			
		CSTD065	68 S LAKESHORE DR	A	Y			
		CSTD066	92 S LAKESHORE DR	A	Y			
		CSTD067	74 S LAKESHORE DR	A	Y			
		CSTD068	86 S LAKESHORE DR	P	Y			
		CSTD069	FIREHOUSE/BAYVIEW DR	P	Y			
		CSTD070	55 LONGVIEW DR	A	Y	3		Y
		CSTD070 - 5	GENERATED BY BATCH	A	Y			
		CSTD071	53 LONGVIEW DR	P	Y			
		CSTD072	48 LONGVIEW DR	P	Y			
		CSTD073	38 LONGVIEW DR	P	Y			
		CSTD074	63 CANDLEWOOD SHRS	P	Y	3		
		CSTD075	2 LILAC LA	P	Y			
		CSTD076	74 KELLOGG ST	P	Y	1		
		CSTD076 - 7	GENERATED BY BATCH	A	Y			
		CSTD077	42 CANDLEWOOD SHRS	A	Y	3		
		CSTD077 - 4	GENERATED BY BATCH	A	Y			
		CSTD078	3 LILAC	A	Y	3		
		CSTD078 - 3	GENERATED BY BATCH	A	Y			
		CSTD079	67 N LAKESHORE DR	P	Y	1		
		CSTD079 - 6	GENERATED BY BATCH	A	Y			
		CSTD080	3 TWILIGHT LA	P	Y	3		
		CSTD080 - 3	GENERATED BY BATCH	A	Y			
		CSTD081	1 TWILIGHT LA	A	Y	3		
		CSTD081 - 1	GENERATED BY BATCH	A	Y			
		CSTD082	PUMP HOUSE	P	Y			
		CSTD083	STORAGE TANK #1	P	Y			
		CSTD084	STORAGE TANK #2	P	Y			
		CSTD100	17 N LAKESHORE DR	A	Y	3		
		CSTD101	154 N LAKE SHORE DRI	A	Y	1		
		CSTD102	170 N LAKE SHORE DRI	A	Y	1		
		CSTD103	172 N LAKE SHORE DRI	A	Y	1		
		CSTD104	44 LONGVIEW DRIVE	A	Y	1		
		CSTD105	3 CIPOLLA LANE	A	Y	1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	C	1,315	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		502					

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CSTD106	22 MOUNTAINVIEW DRIV	A	Y	1		
		CSTD107	24 MOUNTAINVIEW DRIV	A	Y	1		
		CSTD108	31 LAUREL DRIVE	A	Y	1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1642	WELL 1	2	WELL 1	A				
1643	WELL 6	2	WELL 6	A				
1644	WELL 7	2	WELL 7	A				
1645	WELL 8	2	WELL 8	A				
1646	WELL 9	2	WELL 9	A				
49190	MAIN STORAGE TANK							
49192	AUXILARY STORAGE TANK							
50933	CANDLEWOOD SHORES TREATMENT PLANT							
556	WELL 2	2	WELL 2	A				
557	WELL 3	2	WELL 3	A				

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025

**Water System Facility: CANDLEWOOD SHORES TREATMENT PLANT (WSF ID: 50933)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025

### Contact Information

Name		Organization			Job Title	
Mr. Travis Hyatt		Scalzo Property Management				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
2 Stony Hill Road		Suite 201		Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-790-6888	683	203-790-9390		203-790-6888	thyatt@scalzoproperty.com	
Contact Role(s):		Administrative Contact, Legal Contact				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0180061</b>	<b>CANDLEWOOD SHORES TAX DISTRICT</b>	<b>C</b>	<b>1,315</b>	<b>L</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			502					
Towns Served: BROOKFIELD, NEW FAIRFIELD								
Name			Organization			Job Title		
<b>Mr. Angelo Aldana</b>			Candlewood Shores Tax District			President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
55 Longview Dr						Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
646-263-4599					angelo.aldana.director@candlewoodshores.com			
Contact Role(s): <b>Owner</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
20 CHESTER (ARRHDPT049)	1/1/24 - 12/31/24	9/1-9/30	Complete		
	1/1/25 - 12/31/25	9/1-9/30			
	1/1/26 - 12/31/26	9/1-9/30			
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30			
	1/1/28 - 12/31/30	6/1-9/30			
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180091</b>	<b>ARROWHEAD POINT HOMEOWNERS ASSN INC.</b>	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

**Water System Facility: ENTRY POINT - WELLS 2 & 3 (WSF ID: 00702)**

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	1/1/20 - 12/31/25		
	1/1/26 - 12/31/31		

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	1/1/26 - 12/31/28		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Water System Facility: WELL 3 (WSF ID: 56426)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180091</b>	<b>ARROWHEAD POINT HOMEOWNERS ASSN INC.</b>	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

## Monitoring Requirements

Water System Facility: **WELL 3** (WSF ID: 56426)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 2** (WSF ID: 626)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 2 & 3** (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 11/1/2019	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180091</b>	<b>ARROWHEAD POINT HOMEOWNERS ASSN INC.</b>	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

## Water System Facility: ENTRY POINT - WELLS 2 & 3 (WSFID: 00702)

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 11/1/2019	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
4/1/2025 - 4/30/2025			

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	SINGLE FAMILY HOME	A	Y			
		ARRHDPT001	2 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT002	3 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT003	4 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT004	9 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT005	13 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT006	14 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT007	15 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT008	18 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT009	19 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT010	22 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT011	23 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT012	24 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT013	27 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT014	28 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT015	30 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT016	31 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT017	32 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT018	33 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT019	36 ARROWHEAD ROAD	A	Y	3		Y
		ARRHDPT020	37 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT021	38 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT022	40 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT023	41 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT024	42 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT025	43 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT026	44 ARROWHEAD ROAD	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ARRHDPT027	46 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT028	47 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT029	52 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT030	54 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT031	55 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT032	56 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT033	58 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT034	60 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT035	62 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT036	64 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT037	68 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT038	72 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT039	74 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT040	76 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT041	78 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT042	1 CHESTER	A	Y	3		
		ARRHDPT043	6 CHESTER	A	Y	3		
		ARRHDPT044	10 CHESTER	A	Y	3		
		ARRHDPT045	15 CHESTER	A	Y	3		
		ARRHDPT046	16 CHESTER	A	Y	3		
		ARRHDPT047	18 CHESTER	A	Y	3		
		ARRHDPT048	19 CHESTER	A	Y	3		
		ARRHDPT049	20 CHESTER	A	Y	3		Y
		ARRHDPT050	23 CHESTER	A	Y	3		
		ARRHDPT051	24 CHESTER	A	Y	3		
		ARRHDPT052	29 CHESTER	A	Y	3		
		ARRHDPT053	31 CHESTER	A	Y	3		
		ARRHDPT054	34 CHESTER	A	Y	3		
		ARRHDPT055	1 TAYLOR	A	Y	3		
		ARRHDPT056	7 TAYLOR	A	Y	3		
		ARRHDPT057	15 TAYLOR	A	Y	3		
		ARRHDPT058	16 TAYLOR	A	Y	3		
		ARRHDPT059	18 TAYLOR	A	Y	3		
		ARRHDPT060	22 TAYLOR	A	Y	3		
		ARRHDPT061	5 MYRON	A	Y	3		
		ARRHDPT062	6 MYRON	A	Y	3		
		ARRHDPT063	4 MORTON	A	Y	3	Y	
		ARRHDPT064	6 MORTON	A	Y	3		
		ARRHDPT065	8 MORTON	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.	C	296	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ARRHDPT066	89 KELLOGG	A	Y	3		
		ARRHDPT067	91 KELLOGG	A	Y	3		
		ARRHDPT068	94 KELLOGG	A	Y	3	Y	
		ARRHDPT069	95 KELLOGG	A	Y	3		
		ARRHDPT070	96 KELLOGG	A	Y	3		
		ARRHDPT071	97 KELLOGG	A	Y	3		
		ARRHDPT072	98 KELLOGG	A	Y	3		
		ARRHDPT073	100 KELLOGG	A	Y	N		
		ARRHDPT074	102 KELLOGG	A	Y	3		
		ARRHDPT075	104 KELLOGG	A	Y	3		
		ARRHDPT076	83 KELLOGG	A	Y	3		
		ARRHDPT077	#9 CHESTER STREET	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00702	ENTRY POINT - WELLS 2 & 3	3	ENTRY POINT - WELLS	A				
56426	WELL 3	2	WELL 3	A				
56430	ATMOSPHERIC TANK							
56433	PUMP STATION							
61599	TREATMENT PLANT							
626	WELL 2	2	WELL 2	A				

### Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification:</b> SMALL WATER SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2025
<b>Water System Facility: TREATMENT PLANT (WSF ID: 61599)</b>			
<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2025

### Contact Information

Name	Organization	Job Title		
Mr. Joe Voves	Arrowhead Point Hoa	President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180091</b>	<b>ARROWHEAD POINT HOMEOWNERS ASSN INC.</b>	<b>C</b>	<b>296</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							
PO Box 143			Brookfield		CT	06804	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-733-7417					joe@diplomaframe.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180101</b>	<b>AQUARION-HICKORY HILLS</b>	C	132	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
HICKORY HILL SS (02936)	1/1/24 - 12/31/24	7/1-9/30	Complete		
	1/1/25 - 12/31/25	7/1-9/30			
	1/1/26 - 12/31/26	7/1-9/30			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
HICKORY HILL SS (02936)	1/1/24 - 12/31/24	7/1-9/30	Complete		
	1/1/25 - 12/31/25	7/1-9/30			
	1/1/26 - 12/31/26	7/1-9/30			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/25	6/1-9/30			
	1/1/26 - 12/31/26	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180101</b>	<b>AQUARION-HICKORY HILLS</b>	C	132	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Water System Facility: **WELL 4 (WSF ID: 55061)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 2 [UPPER] (WSF ID: 651)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180101	AQUARION-HICKORY HILLS	C	132	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: WELL 2 [UPPER] (WSF ID: 651)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LOWER WELL 2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: WELL 3 (WSF ID: 652)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 11/1/2019	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	02936	HICKORY HILL SS	A	Y		Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180101</b>	<b>AQUARION-HICKORY HILLS</b>	<b>C</b>	<b>132</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		HICKORY001	21 HICKORY HILL RD	A	Y	3		
		HICKORY002	14 HICKORY HILL RD	A	Y	3	Y	
		HICKORY003	22 HICKORY HILL RD	A	Y	3		
		HICKORY004	26 LAUREL DR	A	Y	3		
		HICKORY005	37 LAUREL DR	A	Y	3		
		HICKORY006	9 LAUREL DR	A	Y	3		
		HICKORY007	15 HICKORY HILL RD	A	Y	3		
		HICKORY008	9 HICKORY HILL RD	A	Y	3		
		HICKORY009	17 HICKORY HILL RD	A	Y	3		
		PB8626	4 HICKORY HILL RD	A		3		
		PB8627	7 HICKORY HILL RD	A		3		
		PB8628	14 HICKORY HILL ROAD	A		3		
		PB8629	21 HICKORY HILL RD	A		3		
		PB8630	31 HICKORY HILL RD	A		3		
		PB8631	6 LAUREL DR	A		3		
		PB8632	10 LAUREL DR	A		3		
		PB8633	21 LAUREL DR	A		3		
		PB8634	28 LAUREL DR	A		3		
		PB8635	33 LAUREL DR	A		3		
		PB8637	20 HICKORY HILL RD	A		3		
		PB8720	9 HICKORY HILL RD	A	Y	3		
		PB8721	22 HICKORY HILL RD	A	Y	3		
		PB8722	33 HICKORY HILL RD	A	Y	3		
		PB8723	11 LAUREL DR	A	Y	3		
		PB8724	26 LAUREL DR	A	Y	3		
		PB8725	37 LAUREL DR	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
37275	HYDROPNEUMATIC TANK #2							
37276	ATMOSPHERIC TANK #1							
37278	ATMOSPHERIC TANK #2							
55061	WELL 4	2	WELL 4	A				
61603	TREATMENT PLANT							
651	WELL 2 [UPPER]	2	LOWER WELL 2	A				
652	WELL 3	2	WELL 3	A				

### Certified Operator Information

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180101</b>	<b>AQUARION-HICKORY HILLS</b>	<b>C</b>	<b>132</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						<b>38</b>	

Towns Served: BROOKFIELD

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:**

Operator Name	Operator Type	Certification(s)	Certification Expiration
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

Water System Facility: **TREATMENT PLANT (WSF ID: 61603)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2025
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026

## Contact Information

Name		Organization		Job Title		
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct		Vp-Supply & Utility		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Aquarion Water Company of Ct		505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	C	147	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
29 ARAPAHO DRIVE (04810)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31			
	1/1/26 - 12/31/26	7/1-7/31			
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	C	147	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	<b>C</b>	<b>147</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WELL 1 (WSF ID: 661)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 2 (WSF ID: 662)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 3 (WSF ID: 663)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 5 (WSF ID: 675)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	10/1/24 - 12/31/24		Out of Service
	1/1/25 - 3/31/25		Out of Service
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL 6 (WSF ID: 676)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	C	147	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **WELL 6 (WSF ID: 676)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2005	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
RESPOND TO SANITARY SURVEY	5/14/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04810	29 ARAPAHO DRIVE	A	Y			Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7485	13 APACHE DRIVE	A		3		
		PB7486	834 OBTUSE ROAD SOUT	A	Y	3		
		PB7487	17 CHEROKEE DRIVE	A	Y	3		
		PB7488	44 ARAPAHO ROAD	A	Y	3		
		PB7489	51 ARAPAHO ROAD	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	<b>C</b>	<b>147</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				
Towns Served: BROOKFIELD							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7490	14 CHEROKEE DRIVE	A	Y	3		
		PB8483	4 NAVAHO DRIVE	A		3		
		PB8484	5 APACHE DR	A		1		
		PB8485	6 APACHE DR	A		1		
		PB8486	11 APACHE DR	A		1		
		PB8487	12 CHEROKEE DR	A		1		
		PB8488	36 ARAPAHO ROAD	A		1		
		PB8489	42 ARAPAHO RD	A		1		
		PB8956	8 APACHE DRIVE	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
37026	ATMOSPHERIC TANK 1							
37028	HYDROPNEUMATIC TANK							
54357	ATMOSPHERIC TANK 2							
60164	BOOSTER PUMP STATION							
661	WELL 1	2	WELL 1	A				
662	WELL 2	2	WELL 2	A				
663	WELL 3	2	WELL 3	A				
675	WELL 5	2	WELL 5	A				
676	WELL 6	2	WELL 6	A				
880	INDIAN FIELDS TREATMENT PLANT							

### Certified Operator Information

**Water System Facility: INDIAN FIELDS TREATMENT PLANT (WSF ID: 880)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2025
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180131</b>	<b>AQUARION-INDIAN FIELDS</b>	<b>C</b>	<b>147</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				
Towns Served: BROOKFIELD							

## Contact Information

Name		Organization			Job Title			
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct			Vp-Supply & Utility			
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
Aquarion Water Company of Ct		505 Huntington St.			Shelton		CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180171</b>	<b>BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS</b>	C	144	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			36				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180171</b>	<b>BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS</b>	C	144	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			36				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR CERTIFICATION FORM	12/18/2008	
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	UNIT 1	A	Y	3		
		4-10	UNIT 10	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180171</b>	<b>BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS</b>	<b>C</b>	<b>144</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		36					

Towns Served: BROOKFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		4-11	UNIT 11	A	Y	3		
		4-13	UNIT 13	A	Y	3	Y	
		4-14	UNIT 14	A	Y	3		
		4-15	UNIT 15	A	Y	3		
		4-16	UNIT 16	A	Y	3		
		4-17	UNIT 17	A	Y	3		
		4-18	UNIT 18	A	Y	3		
		4-19	UNIT 19	A	Y	3		
		4-2	UNIT 2	A	Y	3		
		4-20	UNIT 20	A	Y	3		
		4-21	UNIT 21	A	Y	3		
		4-22	UNIT 22	A	Y	3		
		4-23	UNIT 23	A	Y	3		
		4-24	UNIT 24	A	Y	3		
		4-25	UNIT 25	A	Y	3		
		4-26	UNIT 26	A	Y	3		
		4-27	UNIT 27	A	Y	3		
		4-28	UNIT 28	A	Y	3		
		4-29	UNIT 29	A	Y	3		
		4-3	UNIT 3	A	Y	3		
		4-30	UNIT 30	A	Y	3		
		4-31	UNIT 31	A	Y	3		
		4-32	UNIT 32	A	Y	3		
		4-33	UNIT 33	A	Y	3		
		4-34	UNIT 34	A	Y	3		
		4-35	UNIT 35	A	Y	3		
		4-36	UNIT 36	A	Y	3		
		4-4	UNIT 4	A	Y	3		
		4-5	UNIT 5	A	Y	3		
		4-6	UNIT 6	A	Y	3		
		4-7	UNIT 7	A	Y	3		
		4-8	UNIT 8	A	Y	3		
		4-9	UNIT 9	A	Y	3		
		C	UNIT 12	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55766	ATMOSPHERIC STORAGE							
55769	HYDROPNEUMATIC TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180171</b>	<b>BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS</b>	<b>C</b>	<b>144</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		36					

Towns Served: BROOKFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
639	WELL 2	2	WELL 2	A				
640	WELL 1	2	WELL 1	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

## Contact Information

Name		Organization		Job Title		
<b>Mr. Richard Stoeppel</b>		Rrs Management LLC		Association Manager		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1704 Eaton Court				Danbury	CT	06811
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-748-0894					contact@rrspropertymgt.com	

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP	C	144	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
14 LAKEVIEW RD. (LAKE14)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
17 KELLOGG ST. (KELL17)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25				
	7/1/25 - 12/31/25				
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP	C	144	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: BROOKFIELD, NEW FAIRFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180181</b>	<b>CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP</b>	<b>C</b>	<b>144</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: BROOKFIELD, NEW FAIRFIELD

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

Water System Facility: **WELL 1 (WSF ID: 1647)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 2 (WSF ID: 1648)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

--

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180181</b>	<b>CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP</b>	C	144	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			37				

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 9/1/2007	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2028	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		KELL10	10 KELLOGG ST.	A	Y	3	Y	Y
		KELL12	12 KELLOGG ST.	A	Y	3	Y	Y
		KELL13	13 KELLOGG ST.	A	Y	3	Y	Y
		KELL17	17 KELLOGG ST.	A	Y	3	Y	Y
		KELL19	19 KELLOGG ST.	A	Y	3	Y	Y
		KELL5	5 KELLOGG ST.	A	Y	3	Y	Y
		KELL9	9 KELLOGG ST.	A	Y	3	Y	Y
		LAKE11	11 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE12	12 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE13	13 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE14	14 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE15	15 LAKEVIEW RD.	A	Y	1	Y	Y
		LAKE17	17 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE18	18 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE20	20 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE21	21 LAKEVIEW RD.	A	Y	3		Y
		LAKE22	22 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE23	23 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE24	24 LAKEVIEW RD	A	Y	3	Y	Y

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180181</b>	<b>CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP</b>	<b>C</b>	<b>144</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		37					

Towns Served: BROOKFIELD, NEW FAIRFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LAKE25	25 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE26	26 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE27	27 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE29	29 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE2A	2A LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE31	31 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE33	33 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE4	2 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE5	5 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE6	6 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE7	7 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE8	8 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE9	9 LAKEVIEW RD.	A	Y	3	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1647	WELL 1	2	WELL 1	I				
1648	WELL 2	2	WELL 2	A				
53757	TREATMENT PLANT							

### Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 53757)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

### Contact Information

Name		Organization			Job Title	
<b>Mr. Christopher J. Vauthy</b>		Candlewood Orch Owner Corp.			President	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
14 Lakeview Road				Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-775-2907				917-699-1120	vauthycj@gmail.com	
Contact Role(s): <b>Legal Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0180181</b>	<b>CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP</b>	<b>C</b>	<b>144</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		37						
Towns Served: BROOKFIELD, NEW FAIRFIELD								
Name			Organization			Job Title		
<b>Mr. Todd Zoob</b>						Resident		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
28 Cakeview Rd						Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-733-8585					toddzoob@gmail.com			
Contact Role(s): <b>Administrative Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180201</b>	<b>WOODCREEK VILLAGE CONDOMINIUM ASSN, INC</b>	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30			
	1/1/27 - 12/31/29	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180201	WOODCREEK VILLAGE CONDOMINIUM ASSN, INC	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
RESPOND TO SANITARY SURVEY	8/15/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification Required</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Lead and Copper M&R Violation	10/1/23 -	3	12/3/2024		12/13/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180201</b>	<b>WOODCREEK VILLAGE CONDOMINIUM ASSN, INC</b>	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: BROOKFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WV001	81 PRANGE RD	A	Y	N		
		WV002	77 PRANGE RD	A	Y	N		
		WV003	63 PRANGE RD	A	Y	N		
		WV004	69 PRANGE RD	A	Y	N		
		WV005	57 PRANGE RD	A	Y	N		
		WV006	61 PRANGE RD	A	Y	N		
		WV007	55 PRANGE RD	A	Y	N		
		WV008	49 PRANGE RD	A	Y	N		
		WV009	45 PRANGE RD	A	Y	N		
		WV010	67 PRANGE RD	A		N		
00700	ENTRY POINT	3	ENTRY POINT	A				
37084	ATMOSPHERIC TANK							
60001	TRANSFER PUMPS							
631	WELL 1	2	WELL 1	A				
632	WELL 2	2	WELL 2	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2025

## Contact Information

Name		Organization			Job Title	
<b>Ms. Julie Aurrichio</b>		Rei Property Management			Property Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
2A Ives Street				Danbury	CT	06810
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-744-8400	140				jaurrichio@rei-pm.net	
Contact Role(s): <b>Administrative Contact, Legal Contact</b>						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180201</b>	<b>WOODCREEK VILLAGE CONDOMINIUM ASSN, INC</b>	<b>C</b>	<b>72</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		24					

Towns Served: **BROOKFIELD**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180231</b>	<b>LAKE LILLINONAH SHORES CONDOS</b>	<b>C</b>	<b>130</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			48				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>3 repeat (RP) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/14/24 - 12/19/24		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180231	LAKE LILLINONAH SHORES CONDOS	C	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			48				

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180231</b>	<b>LAKE LILLINONAH SHORES CONDOS</b>	C	130	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		48					

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			

Water System Facility: **WELL 1 (WSF ID: 629)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL 1 (2)	12/13/24 - 12/19/24		Complete	

Water System Facility: **WELL 2 (WSF ID: 630)**

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL 2 (2)	12/13/24 - 12/19/24		Complete	

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SANITARY DEFECT CORRECTIVE ACTION	11/10/2024	10/21/2024
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
SANITARY DEFECT CORRECTIVE ACTION	4/1/2027	
CROSS CONNECTION SURVEY REPORT	3/1/2030	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LLSA001	45 HEARTHSTONE	P	Y	2		
		LLSA002	18 HEARTHSTONE	P	Y	2		
		LLSA003	13 HEARTHSTONE	P	Y	2		
		LLSA004	23 HEARTHSTONE	P	Y	2		
		LLSA005	26 HEARTHSTONE	P	Y	2		
		LLSA006	7 HEARTHSTONE	P	Y			
		LLSA007	22 HEARTHSTONE	A	Y			
		LLSA008	16 HEARTHSTONE	P	Y			
		LLSA009	2 HEARTHSTONE	A	Y			
		LLSA010	24 HEARTHSTONE	P	Y			
		LLSA011	30 HEARTHSTONE	P	Y			
		LLSA012	48 HEARTHSTONE	P	Y			
		LLSA013	12 HEARTHSTONE	P	Y			
		LLSA014	37 HEARTHSTONE	P	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180231</b>	<b>LAKE LILLINONAH SHORES CONDOS</b>	<b>C</b>	<b>130</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		48					

Towns Served: BROOKFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LLSA015	25 HEARTHSTONE	P	Y			
		LLSA016	41 HEARTHSTONE	A	Y			
		LLSA017	5 HEARTHSTONE	A				
		LLSA018	10 HEARTHSTONE	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
51805	ATMOSPHERIC STORAGE							
51807	PRESSURE STORAGE							
59124	BOOSTER STATION							
629	WELL 1	2	WELL 1	A				
630	WELL 2	2	WELL 2	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

## Contact Information

Name		Organization		Job Title		
<b>Mr. Richard S. Baldelli</b>		Lake Lillinonah Shores Condo		President Llsca #1		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Llsca No. 1		P.O. Box 97		Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
			203-470-7313		rbaldelli@charter.net	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180251</b>	<b>STONY HILL VILLAGE CONDOMINIUM ASSN</b>	C	392	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			162				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30				
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25		Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180251</b>	<b>STONY HILL VILLAGE CONDOMINIUM ASSN</b>	C	392	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			162				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Uranium (4006)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180251</b>	<b>STONY HILL VILLAGE CONDOMINIUM ASSN</b>	C	392	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		162					

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2029	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UNIT1	UNIT 1	A	Y	3	Y	
		UNIT10	UNIT 10	A	Y	3		
		UNIT102	UNIT 102	A	Y	3		
		UNIT112	UNIT 112	A	Y	3		
		UNIT114	UNIT 114	A	Y	3		
		UNIT121	UNIT 121	A	Y	3		
		UNIT123	UNIT 123	A	Y	3	Y	
		UNIT13	UNIT 13	A	Y	3	Y	
		UNIT134	UNIT 134	A	Y	3		
		UNIT136	UNIT 136	A	Y	3		
		UNIT137	UNIT 137	A	Y	3	Y	
		UNIT138	UNIT 138	A	Y	3	Y	
		UNIT139	UNIT 139	A	Y	3	Y	
		UNIT145	UNIT 145	A	Y	3	Y	
		UNIT146	UNIT 146	A	Y	3	Y	
		UNIT15	UNIT 15	A				
		UNIT154	UNIT 154	A	Y	3		
		UNIT158	UNIT 158	A	Y	3		
		UNIT16	UNIT 16	A	Y	3		
		UNIT17	UNIT 17	A	Y	3		
		UNIT18	UNIT 18	A	Y	3		
		UNIT24	UNIT 24	A	Y	3	Y	
		UNIT25	UNIT 25	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0180251</b>	<b>STONY HILL VILLAGE CONDOMINIUM ASSN</b>	C	392	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		162					

Towns Served: BROOKFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UNIT26	UNIT 26	A	Y	3	Y	
		UNIT3	UNIT 3	A	Y	3		
		UNIT31	UNIT 31	A	Y	3		
		UNIT32	UNIT 32	A	Y	3	Y	
		UNIT34	UNIT 34	A	Y	3		
		UNIT4	UNIT 4	A	Y	3		
		UNIT41	UNIT 41	A	Y	3	Y	
		UNIT49	UNIT 49	A	Y	3	Y	
		UNIT51	UNIT 51	A	Y	3	Y	
		UNIT55	UNIT 55	A	Y	3		
		UNIT58	UNIT 58	A	Y	3		
		UNIT64	UNIT 64	A	Y	3	Y	
		UNIT79	UNIT 79	A	Y	3	Y	
		UNIT85	UNIT 85	A	Y	3	Y	
		UNIT86	UNIT 86	A	Y	3		
		UNIT97	UNIT 97	A	Y	3	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55762	ATMOSPHERIC STORAGE							
55764	PRESSURE STORAGE							
598	WELL 2	2	WELL 2	A				
599	WELL 3	2	WELL 3	A				
60246	WELL 5	2	WELL 5	A				
62826	WELL 6	2	WELL 6	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

## Contact Information

Name			Organization			Job Title			
Mr. Timothy O'neil			Rei Property & Asset Mgmt			Property Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
2A Ives Street						Danbury		CT	06810
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-744-8400	149			203-233-3840	toneil@rei-pm.net				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0180251</b>	<b>STONY HILL VILLAGE CONDOMINIUM ASSN</b>	<b>C</b>	<b>392</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			162					
Towns Served: BROOKFIELD								
Contact Role(s): <b>Administrative Contact, Legal Contact</b>								
Name			Organization			Job Title		
<b>Ms. Kimberly S. O'rouke</b>			Stony Hill Village Board			Board President		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1 Stony Hill Village						Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-470-1465					kimberlyshv@gmail.com			
Contact Role(s): <b>Legal Contact, Owner</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0184011</b>	<b>BROOKFIELD HOUSING AUTHORITY</b>	C	37	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BROOKFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		Complete		
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
4-4 BROOKS QUARY (C4-4)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31	Complete		
	1/1/26 - 12/31/26	8/1-8/31	Complete		
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
2-4 BROOKS QUARY (A2-4)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31	Complete		
	1/1/26 - 12/31/26	8/1-8/31	Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25		Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0184011</b>	<b>BROOKFIELD HOUSING AUTHORITY</b>	<b>C</b>	<b>37</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0184011</b>	<b>BROOKFIELD HOUSING AUTHORITY</b>	C	37	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BROOKFIELD

## Monitoring Requirements

Water System Facility: **WELL 1 (WSF ID: 1650)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 12/1/2009	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

## Other Compliance Schedules

<b>Compliance Schedule Activity</b>	<b>Due Date</b>	<b>Achieved Date</b>
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CCTS 5: PWS OCCT INSTALLATION	5/16/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

## Water System Facility and Sampling Point Inventory

<b>Water System Facility ID</b>	<b>Water System Facility</b>	<b>Sampling Point ID</b>	<b>Sampling Point Description</b>	<b>Status</b>	<b>Total Coliform Rule</b>	<b>Lead and Copper Rule Tier</b>	<b>Asbestos</b>	<b>WQP 2</b>	<b>Stage DBPR</b>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
		A2-4	2-4 BROOKS QUARY	I	Y	1	Y	Y	Y
		B3-2	3-2 BROOKS QUARY	I	Y	1	Y	Y	
		BHA 1-1	APT 1-1	A	Y	1	Y	Y	
		BHA 1-2	APT 1-2	A	Y	1	Y	Y	
		BHA 1-3	APT 1-3	A	Y	1	Y	Y	
		BHA 1-4	APT 1-4	A	Y	1	Y	Y	
		BHA 2-1	APT 2-1	A	Y	1	Y	Y	
		BHA 2-2	APT 2-2	A	Y	1		Y	
		BHA 2-3	APT 2-3	A	Y	1		Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0184011</b>	<b>BROOKFIELD HOUSING AUTHORITY</b>	C	37	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BROOKFIELD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
		BHA 2-4	APT 2-4	A	Y	1		Y	
		BHA 3-1	APT 3-1	A	Y	1		Y	
		BHA 3-2	APT 3-2	A	Y	1		Y	
		BHA 3-3	APT 3-3	A	Y	1		Y	
		BHA 4-1	APT 4-1	A	Y	1			
		BHA 4-2	APT 4-2	A	Y	1			
		BHA 4-3	APT 4-3	A	Y	1			
		BHA 4-4	APT 4-4	A	Y	1			
		BHA 5-1	APT 5-1	A	Y	1			
		BHA 5-2	APT 5-2	A	Y	1			
		BHA 5-3	APT 5-3	A	Y	1			
		BHA 5-4	APT 5-4	A	Y	1			
		BHA 6-1	APT 6-1	A	Y	1			
		BHA 6-2	APT 6-2	A	Y	1			
		BHA 6-3	APT 6-3	A	Y	1			
		BHA 6-4	APT 6-4	A	Y	1			
		BHA 7-1	APT 7-1	A	Y	1			
		BHA 7-2	APT 7-2	A	Y	1			
		BHA 7-3	APT 7-3	A	Y	1			
		BHA 7-4	APT 7-4	A	Y	1			
		BHA 8-1	APT 8-1	A	Y	1			
		BHA 8-2	APT 8-2	A	Y	1			
		BHA 8-3	APT 8-3	A	Y	1			
		BHA 8-4	APT 8-4	A	Y	1			
		BHA 9-1	APT 9-1	A	Y	1			
		BHA 9-2	APT 9-2	A	Y	1			
		BHA 9-3	APT 9-3	A	Y	1			
		BHA 9-4	APT 9-4	A	Y	1			
		BHA OFF	OFFICE-KITCHEN	A	Y	1			
		C4-4	4-4 BROOKS QUARY	I	Y	1	Y	Y	Y
		D5-2	5-2 BROOKS QUARY	I	Y	1	Y	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		E-64	6-4 BROOKS QUARY	I	Y	1	Y	Y	
		F-3	3 BROOKS QUARRY RD,	I					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
1650	WELL 1	2	WELL 1	A					
50373	ATMOSPHERIC STORAGE TANK								
56627	TREATMENT PLANT								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0184011</b>	<b>BROOKFIELD HOUSING AUTHORITY</b>	<b>C</b>	<b>37</b>	<b>L</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		11					

Towns Served: BROOKFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
60312	BOOSTER PUMP							

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 56627)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

## Contact Information

Name		Organization			Job Title		
<b>Ms. Alison Shears</b>		Demarco Management Corporation			Property Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
3 Brooks Quarry Road					Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-775-1403		860-955-2689		203-379-8570	ashears@demarcomc.com		

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title		
<b>Ms. Amelia Malanaphy</b>		Brookfield Housing Authority			Chair		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
57 Carmen Hill Road					Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
			203-885-8392		amalanaphy@yahoo.com		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Brookfield Housing Authority</b>							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
126A Laurel Hill Rd					Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-775-1403							

Contact Role(s): **Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0189971</b>	<b>39 HOP BROOK RD - APT COMPLEX</b>	C	36	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD			12				
Towns Served: BROOKFIELD							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25		Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Chloride (1017)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0189971	39 HOP BROOK RD - APT COMPLEX	C	36	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD			12				
Towns Served: BROOKFIELD							

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Chloride (1017)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/21 - 12/31/26		Complete		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION EXEMPTION	3/1/2028	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0189971</b>	<b>39 HOP BROOK RD - APT COMPLEX</b>	<b>C</b>	<b>36</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD			12				
Towns Served: BROOKFIELD							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	100	COMMUNITY ROOM	A	Y	N	Y	Y
		100 - COMMU	GENERATED BY BATCH	A	Y			
		101	APT 1	A	Y	N	Y	Y Y
		101 - APT 1	GENERATED BY BATCH	A	Y			
		104	APT 4	A		N	Y	
		104 - APT 4	GENERATED BY BATCH	A	Y			
		106	APT 6	A		N	Y	Y
		106 - APT 6	GENERATED BY BATCH	A	Y			
		112	APT 12	A		N	Y	Y Y
		112 - APT 1	GENERATED BY BATCH	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
59965	ATMOSPHERIC STORAGE							
59967	BOOSTER PUMPS							
62389	WELL 2	2	WELL 2	A				

## Certified Operator Information

<b>Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
<b>Facility Classification: SMALL WATER SYSTEM</b>			<b>Certification Expiration</b>
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

## Contact Information

Name		Organization			Job Title		
Mr. Adriano Echavarría		39 Hop Brook Road LLC			LLC Manager/Owner		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
95 Deer Hill Ave					Danbury	CT	06810
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
646-596-1444					echavarría11@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*