

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130011</b>	<b>PORTLAND WATER DEPARTMENT</b>	C	5,010	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>	<b>6 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>6 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>2 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
69 BARLETT ST PUMP ST. (PORT 10)	10/1/24 - 12/31/24	10/1-10/31	Complete
	1/1/25 - 3/31/25	1/1-1/31	Complete
	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	
379 OLD MARLBOROUGH TPK (PORT2D)	10/1/25 - 12/31/25	10/1-10/31	
	10/1/24 - 12/31/24	10/1-10/31	Complete
	1/1/25 - 3/31/25	1/1-1/31	Complete
	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	
	10/1/25 - 12/31/25	10/1-10/31	
<b>Lead And Copper (PBCU)</b>	<b>20 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1130011	PORTLAND WATER DEPARTMENT	C	5,010	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	6 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Gross Beta Particle Activity (4100)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Tritium (4102)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130011</b>	<b>PORTLAND WATER DEPARTMENT</b>	C	5,010	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Strontium-90 (4174)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **GLASTONBURY RD WELL 1 (WSF ID: 434)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GLASTONBURY RD WELL (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130011</b>	<b>PORTLAND WATER DEPARTMENT</b>	C	5,010	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

### Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 2/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	12/1/2024 - 12/31/2024		
	1/1/2025 - 1/31/2025		
	2/1/2025 - 2/28/2025		
	3/1/2025 - 3/31/2025		
	4/1/2025 - 4/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	001	RESERVOIR TANK	A	Y	2		
		002	WELL TREATED/DRAW	A	Y	2		
		003	505 G'BURY TPKE	A	Y	2		
		004	236 PALEY FARM RD	A	Y	3		
		005	72 HIGH STREET	A	Y	3		
		006	226 MAIN STREET	A	Y	2		
		007	217 PICKERING STREET	A	Y	2		
		008	ROSE HILL ROAD	I	Y	3		
		010	LOWER MAIN STREET	A		2		
		011	29 MYRTLE ROAD	A		3		
		012	111 COX ROAD	A		3		
		013	63 COX ROAD	A		3		
		014	64 FREESTONE AVE.	A		3		
		015	481 MAIN STREET	A		3		
		016	20 TUCCITTO ROAD	A		3		
		017	4 SUSAN CIRCLE	A		3		
		018	180 OLD MARLBOROUGH	A		3		
		019	19 TAYLOR DRIVE	A		3		
		020	9 SCENIC DRIVE	A		3		
		021	16 SPRING STREET	A		3		
		022	24 WILLIAM STREET	A		3		
		023	40 EDGEWOOD ROAD	A		3		
		024	430 MAIN STREET	A		3		
		025	24 PICKERING STREET	I		2		
		026	29 CHURCH STREET	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130011</b>	<b>PORTLAND WATER DEPARTMENT</b>	C	5,010	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		027	GLORIA HEIGHTS	I		3		
		028	55 EAST MAIN STREET	A		3		
		029	20 BELL COURT	A		3		
		030	5 DOGWOOD DRIVE	A		2		
		031	224 COX ROAD	A		3		
		032	328 MAIN STREET	A		3		
		033	1 MICHAEL DRIVE	A		3		
		034	32 EAST MAIN STREET	A		3		
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PORT 10	69 BARLETT ST PUMP S	A				Y
		PORT1	MDC ENTRY	A	Y			
		PORT1D	956 GLASTONBURY RD	A	Y			
		PORT1U	DRAGHI FARM STAND	A	Y			
		PORT2	RESERVOIR TANK	A	Y			
		PORT2D	379 OLD MARLBOROUGH	A	Y			Y
		PORT2U	RESERVOIR TANK IN	A	Y			
		PORT3	594 MAIN - FIRE CO 2	A	Y			
		PORT3D	575 MAIN -GUILDER SC	A	Y			
		PORT3U	634 MAIN-CELLAR SAVE	A	Y			
		PORT4	265 MAIN - POLICE	A	Y			
		PORT4D	245 MAIN - LIB BANK	A	Y			
		PORT4U	269 MAIN - BANK AMER	A	Y			
		PORT5	81 HIGH -VALLEY VIEW	A	Y			
		PORT5D	44 HIGH - GREYSTONE	A	Y			
		PORT5U	95 HIGH -HIGH SCHOOL	A	Y			
		PORT6	WASTEWATER PLANT	A	Y			
		PORT6D	1 LOW MAIN - ANIMAL	A	Y			
		PORT6U	LOWER MAIN	A	Y			
		PORT9	HIGH STREET TANK	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
232	WELL TREATMENT STATION							
434	GLASTONBURY RD WELL 1	2	GLASTONBURY RD WELL	A				
44955	INTERCONNECTION - CT0640011 - ROUTE 17							
47020	2 RESERVOIR STORAGE TANKS							
47022	HIGH STREET TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130011</b>	<b>PORTLAND WATER DEPARTMENT</b>	<b>C</b>	5,010	<b>L</b>	<b>SWP</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			2,053	240	29		

Towns Served: MIDDLETOWN, PORTLAND

## Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LYNCH, WILLIAM J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2027

**Water System Facility: WELL TREATMENT STATION (WSF ID: 232)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LYNCH, WILLIAM J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2027
ARMSTRONG, KYLE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2025

## Contact Information

Name		Organization			Job Title	
<b>Portland</b>						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	

Contact Role(s): **Owner**

Name		Organization			Job Title	
<b>Mr. Ryan O'halpin</b>		Town of Portland			Dir. of Public Works	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
33 East Main Street				Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-342-6734				908-770-1538	rohalpin@portlandct.org	

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title	
<b>Mr. Ryan Curley</b>		Town of Portland			First Selectman	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
33 East Main Street		P.O. Box 71		Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-342-6715					rcurley@portlandct.org	

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130021</b>	<b>CTWC - RIVERCREST DIVISION</b>	C	88	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LYMAN LANE			22				

Towns Served: PORTLAND

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		Complete		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
SAMPLING STATION (RC5000)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31	Complete		
	1/1/26 - 12/31/26	8/1-8/31	Complete		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/25	6/1-9/30	Complete		
	1/1/26 - 12/31/26	6/1-9/30	Complete		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130021</b>	<b>CTWC - RIVERCREST DIVISION</b>	C	88	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LYMAN LANE			22				
Towns Served: PORTLAND							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

--

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130021</b>	<b>CTWC - RIVERCREST DIVISION</b>	C	88	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LYMAN LANE			22				

Towns Served: PORTLAND

## Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Continuous
<b>Start Date:</b> 1/1/2016		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
<b>Start Date:</b> 12/1/2014		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2029	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RC5000	SAMPLING STATION	A	Y			Y
		RIVC001	6 LYMAN ROAD	A	Y	3		
		RIVC002	10 LYMAN ROAD	I	Y	3		Y
		RIVC003	42 LYMAN ROAD	A	Y	3		
		RIVC004	36 LYMAN ROAD	A	Y	3		
		RIVC005	5 LYMAN ROAD	A	Y	3		
		RIVC006	21 LYMAN ROAD	A	Y	3		
		RIVC007	18 LYMAN ROAD	A	Y	3		
		RIVC009	27 LYMAN	A	Y			
		RIVC010	6 WELLWYN DRIVE	A	Y	1		
		RIVC011	46 WELLWYN DRIVE	A	Y	1		
		RIVC012	2 LYMAN ROAD	A	Y	3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130021</b>	<b>CTWC - RIVERCREST DIVISION</b>	C	88	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
LYMAN LANE			22				
Towns Served: PORTLAND							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		RIVC013	7 LYMAN ROAD	A	Y	3		
		RIVC014	13 LYMAN ROAD	A	Y	3		
		RIVC015	15 LYMAN ROAD	A	Y	3		
		RIVC016	27 LYMAN ROAD	A		3		
		RIVC017	28 LYMAN ROAD	A	Y	3		
		RIVC018	57 PAYNE BLVD	A	Y	3		
		RIVC019	63 PAYNE BLVD	A	Y	3		
		RIVC020	64 PAYNE BLVD	A	Y	3		
		RIVC021	5 WELLWYN DRIVE	A	Y	3		
		RIVC022	10 WELLWYN DRIVE	A	Y	3		
		RIVC023	38 WELLWYN DRIVE	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1490	WELL 5	2	WELL 5	A				
36739	ATMOSPHERIC STORAGE							
36741	PRESSURE TANK							
455	WELL 3	2	WELL 3	A				
52689	PUMP STATION							
574	RIVERCREST PUMP HOUSE							
59383	WELL 6	2	WELL 6	A				

### Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
ANDREWS, PAUL M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2024
Water System Facility: <b>RIVERCREST PUMP HOUSE (WSF ID: 574)</b>			
Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

### Contact Information

Name		Organization			Job Title	
<b>Mr. Craig J. Patla</b>		Connecticut Water Company			Vp, Service Delivery	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1130021</b>	<b>CTWC - RIVERCREST DIVISION</b>	<b>C</b>	<b>88</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
LYMAN LANE			22					
Towns Served: PORTLAND								
860-664-6140		800-391-1924		craig.patla@ctwater.com				
Contact Role(s): <b>Legal Contact, Owner</b>								
Name			Organization			Job Title		
<b>Mr. Gerald McDermott</b>			The Connecticut Water Company			Manager, Service Del		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6125					Gerald.McDermott@ctwater.com			

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130064</b>	<b>SOLANO INN LLC</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1503 PORTLAND COBALT ROAD						13	
Towns Served: PORTLAND							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/26				
<b>Total Coliform (3100)</b>		<b>2 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/25	6/1-9/30			
	1/1/26 - 12/31/26	6/1-9/30			
<b>Physical Parameters (PPS)</b>		<b>2 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				
<b>Water System Facility: ENTRY POINT (WSF ID: 00700)</b>					
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>		<b>1 routine (RT) per six years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/19 - 12/31/24		Complete		
	1/1/25 - 12/31/30				
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130064</b>	<b>SOLANO INN LLC</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1503 PORTLAND COBALT ROAD						13	
Towns Served: PORTLAND							

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2029	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RP1497-F1	FRONT HOTEL UNIT 1	A	Y	N		
		RP1497-F10	FRONT HOTEL UNT 10	A	Y	N		
		RP1497-F11	DISTRIBUTION SYSTEM	A	Y	N		
		RP1497-F12	FRONT HOTEL UNIT 12	A	Y	N		
		RP1497-F13	FRONT HOTEL UNIT 13	A	Y	N		
		RP1497-F14	FRONT HOTEL UNIT 14	A	Y	N		
		RP1497-F2	FRONT HOTEL UNIT 2	A	Y	N		
		RP1497-F3	HOTEL FRONT UNIT 3	A	Y	N		
		RP1497-F4	FRONT HOTEL UNIT 4	A	Y	N		
		RP1497-F5	FRONT HOTEL UNIT 5	A	Y	N		
		RP1497-F6	FRONT HOTEL UNIT 6	A	Y	N		
		RP1497-F7	FRONT HOTEL UNIT 7	A	Y	N		
		RP1497-F8	FRONT HOTEL UNIT 8	A	Y	N		
		RP1497-F9	FRONT HOTEL UNIT 9	A	Y	N		
		RP1497-R1	REAR HOTEL UNIT 1	A	Y	N		
		RP1497-R10	REAR HOTEL UNIT 10	A	Y	N		
		RP1497-R11	REAR HOTEL UNIT 11	A	Y	N		
		RP1497-R12	REAR HOTEL UNIT 12	A	Y	N		
		RP1497-R13	REAR HOTEL UNIT 13	A	Y	N		
		RP1497-R14	REAR HOTEL UNIT 14	A	Y	N		
		RP1497-R15	REAR HOTEL UNIT 15	A	Y	N		
		RP1497-R16	REAR HOTEL UNIT 16	A	Y	N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130064</b>	<b>SOLANO INN LLC</b>	C	96	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1503 PORTLAND COBALT ROAD						13	
Towns Served: PORTLAND							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		RP1497-R17	REAR HOTEL UNIT 17	A	Y	N		
		RP1497-R18	REAR HOTEL UNIT 18	A	Y	N		
		RP1497-R19	REAR HOTEL UNIT 19	A	Y	N		
		RP1497-R2	REAR HOTEL UNIT 2	A	Y	N		
		RP1497-R20	REAR HOTEL UNIT 20	A	Y	N		
		RP1497-R21	REAR HOTEL UNIT 21	A	Y	N		
		RP1497-R22	REAR HOTEL UNIT 22	A	Y	N		
		RP1497-R23	REAR HOTEL UNIT 23	A	Y	N		
		RP1497-R24	REAR HOTEL UNIT 24	A	Y	N		
		RP1497-R3	REAR HOTEL UNIT 3	A	Y	N		
		RP1497-R4	REAR HOTEL UNIT 4	A	Y	N		
		RP1497-R5	REAR HOTEL UNIT 5	A	Y	N		
		RP1497-R6	REAR HOTEL UNIT 6	A	Y	N		
		RP1497-R7	REAR HOTEL UNIT 7	A	Y	N		
		RP1497-R8	REAR HOTEL UNIT 8	A	Y	N		
		RP1497-R9	REAR HOTEL UNIT 9	A	Y	N		
		RP1509-1	8 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-2	9 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-3	10 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-4	11 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-5	12 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-6	13 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-7	14 ROOM HOTEL UNIT 1	A	Y	N		
		RP1509-8	15 ROOM HOTEL UNIT 1	A	Y	N		
		RP1555-U4	1555 P-C RD U4	A	Y	3		
		RP1555-U5	1555 P-C RD U5	A	Y	3		
		RP1555-U6	1555 P-C RD U6	A	Y	3		
		RP1557	1557 P-C RD	A	Y	3		
		RP1559	1559 P-C RD	A	Y	3		
		RP1561	1561 P-C RD	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21966	WELL 1	2	WELL	A				
57384	HYDROPNEUMATIC TANKS							

### Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>			
Facility Classification: SMALL WATER SYSTEM			
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>	<b>Certification Expiration</b>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1130064</b>	<b>SOLANO INN LLC</b>	<b>C</b>	<b>96</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1503 PORTLAND COBALT ROAD						<b>13</b>	
Towns Served: PORTLAND							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

## Contact Information

Name		Organization			Job Title	
<b>Mr. Carlos I Solano</b>		Solano Inn			President	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1503 Portland-Cobalt Road				Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-342-0010				914-760-1700	Solanoinn.Lindaly@gmail.com	

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title	
<b>Ms. Nancy Alvarado</b>		Solano Inn LLC				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1503 Portland-Cobalt Road				Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
914-441-9800					Solanoinn.Lindaly@gmail.com	

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**