

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				

Towns Served: WESTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		Complete		
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
49 RAVENWOOD DR (WRW06)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31	Complete		
	1/1/26 - 12/31/26	8/1-8/31	Complete		
Lead And Copper (PBCU)		5 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25		Complete		
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				

Towns Served: WESTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water Quality Parameters with (WQP3)	2 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				

Towns Served: WESTON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: **WELL 4 (WSF ID: 1825)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **WELL 5 (WSF ID: 1911)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				
Towns Served: WESTON							

Monitoring Requirements

Water System Facility: **WELL 5 (WSF ID: 1911)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		Complete
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 7/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024	Y	
		1/1/2025 - 1/31/2025	Y	
		2/1/2025 - 2/28/2025	Y	
		3/1/2025 - 3/31/2025	Y	
		4/1/2025 - 4/30/2025		
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.5 MG/L	2	
Start Date: 10/1/2021		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024	Y	
		1/1/2025 - 1/31/2025	Y	
		2/1/2025 - 2/28/2025	Y	
		3/1/2025 - 3/31/2025	Y	
		4/1/2025 - 4/30/2025		
Orthophosphate	<spaces> ()	Maximum: 1.8 MG/L	2	
Start Date: 10/1/2021		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				

Towns Served: WESTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	<spaces> ()	Maximum: 1.8 MG/L	2
Start Date: 10/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 7.8 PH	Daily
Start Date: 10/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 10/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW ENTRY POINT	2	RAW ENTRY POINT	A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WRW01	11RAVENWOOD DR	A	Y	3		
		WRW010	270 GODFREY RD EAST	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				
Towns Served: WESTON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WRW011	251 GODFREY RD EAST	A	Y	3		
		WRW012	240 GODFREY RD EAST	A	Y	3		
		WRW013	236 GODFREY RD EAST	A	Y	3		
		WRW014	230 GODFREY RD EAST	A	Y	3		
		WRW015	211 GODFREY RD EAST	A	Y	3		
		WRW016	20 RAVENWOOD DRIVE	A	Y	3		
		WRW017	21 RAVENWOOD DRIVE	A	Y	3		
		WRW018	28 RAVENWOOD DRIVE	A	Y	3		
		WRW019	27 RAVENWOOD DRIVE	A	Y	3		
		WRW02	17 RAVENWOOD DR	A		3		
		WRW020	34 RAVENWOOD DRIVE	A	Y	3		
		WRW021	36 RAVENWOOD DRIVE	A	Y	3		
		WRW022	39 RAVENWOOD DRIVE	A	Y	3		
		WRW023	43 RAVENWOOD DRIVE	A	Y	3		
		WRW024	9 TUBBS SPRING CT	A	Y	3		
		WRW025	11 TUBBS SPRING CT	A	Y	3		
		WRW026	219 GODFREY RD EAST	A	Y	3		
		WRW03	31 RAVENWOOD DR	A	Y	3		
		WRW04	37 RAVENWOOD DR	A	Y	3		
		WRW05	44 RAVENWOOD DR	A		3		
		WRW06	49 RAVENWOOD DR	A	Y	3		Y
		WRW07	227 GODFREY EAST	A		3		
		WRW08	50 RAVENWOOD DR	A		3		
		WRW09	237 GODFREY RD EAST	A	Y	2		
00700	ENTRY POINT	3	ENTRY POINT	A				
1825	WELL 4	2	WELL 4	A				
1911	WELL 5	2	WELL 5	A				
372	WESTON TREATMENT PLANT							
55631	ATMOSPHERIC STORAGE - STANDPIPE							
55633	BOOSTER PUMPS							
55635	PRESSURE TANK							

Certified Operator Information

Water System Facility: WESTON TREATMENT PLANT (WSF ID: 372)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1570011	WESTON WATER SUPPLY	C	100	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
RAVENWOOD			30				

Towns Served: WESTON

Certified Operator Information

Water System Facility: **WESTON TREATMENT PLANT (WSF ID: 372)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2025

Contact Information

Name		Organization		Job Title		
Mr. Larry Roberts		Town of Weston		Pub Works&Facil Mngt		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
56 Norfield Road				Weston	CT	06883
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-222-2662					lroberts@westonct.gov	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule