

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorite (1009)	3 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PUTNAM HIGH SERVICE (05025)	12/1/24 - 12/31/24			
	1/1/25 - 1/31/25			
	2/1/25 - 2/28/25			
	3/1/25 - 3/31/25			
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
GREENWICH HOSPITAL (05036)	12/1/24 - 12/31/24			
	1/1/25 - 1/31/25			
	2/1/25 - 2/28/25			
	3/1/25 - 3/31/25			
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
GLENVILLE SCHOOL SS (05039)	12/1/24 - 12/31/24			
	1/1/25 - 1/31/25			
	2/1/25 - 2/28/25			
	3/1/25 - 3/31/25			
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
Chlorine Residual (1012)	60 routine (RT) per month			
	<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
Asbestos (1094)	2 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GREENWICH HOSPITAL (05036)	1/1/20 - 12/31/28		
NO MIANUS SCHOOL SS (05041)	1/1/20 - 12/31/28		
Total Coliform (3100)	60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	8 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GREENWICH OFFICE (05020)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
CENTRAL F.H. (05021)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
TOWN SHED (05029)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25		
GREENWICH HOSPITAL (05036)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
GLENVILLE F.S. (05037)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
ROUND HILL SS (05038)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
GLENVILLE SCHOOL SS (05039)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
PARSONAGE RD SS (05051)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	
Physical Parameters (PPS)		60 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	60 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: ENTRY POINT - PUTNAM TREATMENT PLANT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		

Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - MIANUS TREATMENT PLANT (WSF ID: 00701)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Water System Facility: PUTNAM LAKE RESERVOIR (WSF ID: 2067)			
Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PUTNAM LAKE RES (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **PUTNAM LAKE RESERVOIR (WSF ID: 2067)**

Total Alkalinity (1927)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Organic Carbon (2920)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PUTNAM LAKE RES (1)	12/1/24 - 12/31/24		Complete	
	1/1/25 - 1/31/25		Complete	
	2/1/25 - 2/28/25		Complete	
	3/1/25 - 3/31/25		Complete	
	4/1/25 - 4/30/25			
	5/1/25 - 5/31/25			
	6/1/25 - 6/30/25			
	7/1/25 - 7/31/25			
	8/1/25 - 8/31/25			
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
Total Coliform (3100)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PUTNAM LAKE RES (1)	10/1/24 - 12/31/24		Complete	
	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PUTNAM LAKE RES (1)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PUTNAM LAKE RES (1)	10/1/24 - 12/31/24		Complete	
	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **PUTNAM LAKE RESERVOIR (WSF ID: 2067)**

Surface Water Color and Turbidity (RPPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PUTNAM LAKE RES (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **MIANUS MILL POND (WSF ID: 2072)**

Total Alkalinity (1927) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Total Organic Carbon (2920) **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	10/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **MIANUS MILL POND (WSF ID: 2072)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Inorganic Chemicals (RIOCI)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MIANUS MILL POND (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: **PUTNAM LAKE FILTER PLANT (WSF ID: 91)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - PUTNAM LAKE (5)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **MIANUS RIVER FILTER PLANT (WSF ID: 92)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Monitoring Requirements

Water System Facility: **MIANUS RIVER FILTER PLANT (WSF ID: 92)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - MIANUS RIVER (5)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - PUTNAM TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily	
Start Date: 6/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		
		1/1/2025 - 1/31/2025		
		2/1/2025 - 2/28/2025		
		3/1/2025 - 3/31/2025		
		4/1/2025 - 4/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 6/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024	Y	
		1/1/2025 - 1/31/2025	Y	
		2/1/2025 - 2/28/2025	Y	
		3/1/2025 - 3/31/2025	Y	
		4/1/2025 - 4/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily	
Start Date: 7/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility: ENTRY POINT - PUTNAM TREATMENT PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: ENTRY POINT - MIANUS TREATMENT PLANT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility: **ENTRY POINT - MIANUS TREATMENT PLANT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: **PUTNAM LAKE FILTER PLANT (WSFID: 91)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine Dioxide Residual	EP Chlorine Dioxide (CLO2)	Maximum: 0.8 MG/L	Daily
Start Date: 7/1/2013		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
	Offline	12/1/2024 - 12/31/2024	n/a
	Offline	1/1/2025 - 1/31/2025	n/a
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility: PUTNAM LAKE FILTER PLANT (WSFID: 91)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorite	EP Chlorite (CLO3)	Maximum: 1.0 MG/L	Daily
Start Date: 7/1/2013		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
	Offline	12/1/2024 - 12/31/2024	n/a
	Offline	1/1/2025 - 1/31/2025	n/a
	Offline	2/1/2025 - 2/28/2025	n/a
	Offline	3/1/2025 - 3/31/2025	n/a
		4/1/2025 - 4/30/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Water System Facility: MIANUS RIVER FILTER PLANT (WSFID: 92)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility: MIANUS RIVER FILTER PLANT (WSFID: 92)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
WATERSHED SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Chlorite M&R Violation	6/1/24 - 6/30/24	3	10/28/2025		11/7/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	05020	GREENWICH OFFICE	A	Y			Y
		05021	CENTRAL F.H.	A	Y			Y
		05022	COS COB F.H.	A	Y			
		05023	EAST PORTCHESTER FH	A	Y			
		05024	HYATT REGENCY	A	Y			
		05025	PUTNAM HIGH SERVICE	A	Y			
		05025D	PUTNAM HIGH SERVICE	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		05025U	PUTNAM HIGH SERVICE	A	Y			
		05026	SOUND BEACH F.H.	A	Y			
		05027	ST PAUL'S CHURCH	A	Y			
		05029	TOWN SHED	A	Y			Y
		05030	HENDRIE ST SCHOOL	A	Y			
		05032	GLENVILLE MIDDLE SCH	A	Y			
		05033	NO MIANUS SCHOOL	A	Y			
		05035	HARBOR HOUSE INN	A	Y			
		05036	GREENWICH HOSPITAL	A	Y		Y	Y
		05037	GLENVILLE F.S.	A	Y			Y
		05038	ROUND HILL SS	A	Y			Y
		05038D	ROUND HILL RD SS - G	A	Y			
		05038U	ROUND HILL RD SS - G	A	Y			
		05039	GLENVILLE SCHOOL SS	A	Y			Y
		05039D	GLENVILLE MIDDLE SCH	A	Y			
		05039U	GLENVILLE MIDDLE SCH	A	Y			
		05040	NATHANIEL WITHERALL	A	Y			Y
		05041	NO MIANUS SCHOOL SS	A	Y		Y	
		05042	HENDRIE ST SCHOOL SS	A	Y			
		05043	239 GLENVILLE ROAD	A	Y			
		05044	123 MASON STREET	I	Y			Y
		05045	COS COB LIBRARY	A	Y			
		05046	2 LINCOLN AVE SS	A				
		05047	GREENWICH MAIN LIBRA	A	Y			
		05048	PERROT LIBRARY-GREEN	A	Y			
		05049	2 LINCOLN AVE SS	A	Y			
		05049D	2 LINCOLN AVE SS G	A	Y			
		05049U	2 LINCOLN AVE SS G	A	Y			
		05050	189 MASON ST - GREEN	I	Y			Y
		05051	PARSONAGE RD SS	A	Y		Y	Y
		05052	FIELD PT CIRCLE SS	A	Y			
		05053	KHAKUM WOODS SS GREE	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6159	27 WOODLAND GRN	A		1		
		PB6160	27 PROSPECT GRNWICH	A		1		
		PB6161	398 SOUND BEACH GRN	A		3		
		PB6162	136 SHORE GRNWICH	A		1		
		PB6163	376 DAVIS GRNWICH	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6164	136 RIVERSIDE AVE	A		1		
		PB6165	3 COS COB COS COB	A		1		
		PB6166	105 RIVERSIDE GRN	A		1		
		PB6167	127 HAVEMEYER GRN	A		1		
		PB6168	144 RIVERSIDE GRN	A		1		
		PB6169	31 BUSH GRNWICH	A		3		
		PB6170	55 SHERWOOD PLACE	A		1		
		PB6171	58 DOUBLING GRNWICH	A		1		
		PB6173	310 SOUND BEACH GRN	A		1		
		PB6174	57 SHERWOOD GRN	A		1		
		PB6175	477 FIELD POINT GRN	A		1		
		PB6177	21 GROVE GRNWICH	A		3		
		PB6178	190 MILBANK GRNWICH	A		1		
		PB6179	2 PATTERSON GRN	A		1		
		PB6180	16 DIVISION ST	A		1		
		PB6182	72 GLENVILLE GRNWICH	A		1		
		PB6183	16 VERONA GRNWICH	A		1		
		PB6184	11 WILLIAM GRNWICH	A		1		
		PB6185	275 RIVERSIDE GRN	A		1		
		PB6186	73 NORTH GRNWICH	A		1		
		PB6187	17 BROOKRIDGE GRN	A		1		
		PB6220	10 FIELD POINT GRN	A		1		
		PB6221	304 SOUND BEACH GRN	A		1		
		PB6222	6 NAWTHORNE RD	A		1		
		PB6223	51 MAYO AVE	A	Y	3		
		PB6227	70 BRUCE PRK GRN	A		1		
		PB6291	1 NEDLEY LA GRN	A		3		
		PB6292	16 OLD WAGON GRN	A		3		
		PB6293	240 RIVERSIDE GRN	A		3		
		PB6295	11 HILLSIDE ROAD	A	Y	3		
		PB6297	2 SOUND VIEW CT GRN	A		3		
		PB6298	39 CIRCLE DR GRN	A		3		
		PB6299	112 HILLCREST COSCOB	A		3		
		PB6300	34 RIDGE RD COS COB	A		3		
		PB6331	1 LEJUNE CT	A	Y	3		
		PB6339	400 VALLEY ROAD	A	Y	3		
		PB6343	1 SOMERSET LANE	A	Y	3		
		PB6344	15 REYNOLDS PLACE	A	Y	2		
		PB6345	7 ROCKLAND PLACE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6346	31 BIBLE ST	A	Y	3		
		PB6347	2 DEER LANE	A	Y	3		
		PB6912	17 LUCY STREET	A	Y	3		
		PB6913	PB6913 - 7 ROCKLAND	A	Y			
		PB7530	7 PARSONAGE LANE	A	Y	1		
		PB7547	PB7547 - 55 STANWICH	A	Y			
		PB8013	12 RANDOLPH PLACE	A		1		
		PB8014	20 ROCKLAND PLACE	A		1		
		PB8015	105 SHORE RD	A		1		
		PB8016	3 HILLSIDE RD	A		1		
		PB8017	275 BRUCE PARK AVE	A		1		
		PB8018	1 SOUND VIEW COURT	A		1		
		PB8019	43 RIVERSIDE AVE	A		1		
		PB8020	19 BUSH AVE	A		1		
		PB8021	67 MAYO AVE	A		1		
		PB8022	36 RIDGE RD	A		1		
		PB8023	35 SHERWOOD PLACE	A		1		
		PB8024	12 DOUBLING RD	A		1		
		PB8025	528 FIELD POINT RD	A		1		
		PB8026	60 FIELD POINT CIRCL	A		1		
		PB8027	23 WOODLAND DR	A		1		
		PB8028	9 GLENVILLE ST	A		1		
		PB8029	29 COS COB AVE	A		1		
		PB8030	1 NORTH ST	A		1		
		PB8031	147 DAVIS AVE	A		1		
		PB8032	32 FIELD POINT RD	A		1		
		PB8033	3 DIVISION ST	A		1		
		PB8034	26 VALLEY RD	A		1		
		PB8035	11 BIBLE ST	A		1		
		PB8036	46 PARSONAGE RD	A		1		
		PB8037	80 STANWICH RD	A		1		
		PB8038	37 KHAKUM WOOD RD	A		1		
		PB8039	38 LOADING ROCK RD	A		1		
		PB8040	60 DUNCAN DRIVE	A		1		
		PB8041	158 CLAPBOARD RIDGE	A		1		
		PB8042	444 OLD CHURCH RD	A		1		
		PB8043	1 ROBERTA LN	A		1		
		PB8044	150 ZACCHEUS MEAD	A		1		
		PB8045	47 DRUID LN	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB8046	45 HOMESTEAD RD	A		1		
		PB8047	35 GREY ROCK RD	A		1		
		PB8048	141 DOUBLING RD	A		1		
		PB8049	102 PARSONAGE RD	A		1		
		PB8050	306 ORCHARD ST	A		1		
		PB8051	33 HILLCREST PARK RD	A		1		
		PB8052	12 SIDNEY LANIER LN	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - PUTNAM TREATMENT PLANT	3	ENTRY POINT	A				
00701	ENTRY POINT - MIANUS TREATMENT PLANT	3	ENTRY POINT	A				
2067	PUTNAM LAKE RESERVOIR	1	PUTNAM LAKE RES	A				
2068	ROCKWOOD LAKE RESERVOIR	1	RESERVOIR	A				
2069	CONVERSE POND BK DIV	1	RESERVOIR	A				
2070	BRUSH RESERVOIR	1	RESERVOIR	A				
2071	BARGH RESERVOIR	1	RESERVOIR	A				
2072	MIANUS MILL POND	1	MIANUS MILL POND	A				
2292	CONVERSE LAKE	1	RESERVOIR	A				
30031	MIANUS POND							
30032	PUTNAM LAKE RSVR							
37130	PUTNAM EAST CLEARWELL							
37132	PUTNAM HIGH SERVICE TANK							
37134	MIANUS CLEARWELL							
37136	KING STREET TANK							
48563	INTERCONNECTION - CT1350011 - HAVEMEYER							
49503	RIDGE AVE PUMP STATION							
49505	PUTNUM H.S. PUMP STATION							
49507	PUTNUM PUMP STATION							
49509	HAVEMEYER LANE PUMP STATION							
49511	MIANUS PLANT PUMP STATION							
57323	GLENVILLE PUMP STATION							
59126	PUTNAM WEST CLEARWELL							
60676	ANDERSON ROAD PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0570011	AQUARION-GREENWICH	C	53,297	P	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,060	

Towns Served: GREENWICH, STAMFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
61583	INTERCONNECTION - CT1350011 -PALMER HILL							
91	PUTNAM LAKE FILTER PLANT	3	ENTRY POINT - PUTNAM	A				
		5	COMBINED FILTER EFFL	A				
92	MIANUS RIVER FILTER PLANT	3	ENTRY POINT - MIANUS	A				
		5	COMBINED FILTER EFFL	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2025

Water System Facility: **PUTNAM LAKE FILTER PLANT (WSF ID: 91)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
VIGUE, EDWARD	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
REPPUCCI, EDWARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
MEDD, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
RICCIARDI, GERALD P.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025

Water System Facility: **MIANUS RIVER FILTER PLANT (WSF ID: 92)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BOWEN, ROSE F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2025
VIGUE, EDWARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
REPPUCCI, EDWARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
MEDD, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027

Contact Information

Name		Organization			Job Title	
Mr. John P. Walsh		Aquarion Water Company			Vice President	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
835 Main Street		Mail Stop 700		Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0570011	AQUARION-GREENWICH			C	53,297	P	SW
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined
							17,060
Towns Served: GREENWICH, STAMFORD							
Name			Organization			Job Title	
Mr. Robert J. Ulrich			Aquarion Water Company of Ct			Vp-Supply & Utility	
Mailing Address Line One			Mailing Address Line Two			City	State
Aquarion Water Company of Ct			505 Huntington St.			Shelton	CT
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320			203-929-5297		203-395-3205	rulrich@aquarionwater.com	
Contact Role(s): Administrative Contact							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete		
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WASTEWATER TP (4650DDBP13)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31	Complete		
	1/1/26 - 12/31/26	7/1-7/31	Complete		
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
1216 KING ST. #1 (4650DDBP14)	1/1/24 - 12/31/24	7/1-7/31	Complete		
	1/1/25 - 12/31/25	7/1-7/31	Complete		
	1/1/26 - 12/31/26	7/1-7/31	Complete		
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
Lead And Copper (PBCU)		20 routine (RT) per six months			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete		
	1/1/25 - 6/30/25		Complete		
	7/1/25 - 12/31/25		Complete		
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL A (WSF ID: 10272)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL A (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: WELL B (WSF ID: 10273)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL B (2)	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: WELL C (WSF ID: 53400)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	12/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Monitoring Requirements

Water System Facility: **WELL C (WSF ID: 53400)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2015		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 6/1/2016		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW ENTRY POINT	2	RAW ENTRY POINT	A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4650-1	ATH FIELD FOUNTAIN	A	Y	N	Y	
		4650-10	ATH BLDG MENS RM	A	Y	N	Y	
		4650-11	3RD FLOOR MENS RM	A	Y	N	Y	
		4650-12	ATH BLDG TRAINER RM	A	Y	N	Y	
		4650-13	RINK OFFICE SINK	A	Y	N	Y	
		4650-2	2ND FLOOR LADIES RM	A	Y	N	Y	
		4650-3	MAINTENANCE DEPT	A	Y	N	Y	
		4650-4	2ND FLOOR MENS RM	A	Y	N	Y	
		4650-5	ATH BLDG LADIES RM	A	Y	N	Y	
		4650-6	KITCHEN SINK	A	Y	N	Y	
		4650-7	ATH BUILDING FOUNT	A	Y	N	Y	
		4650-8	3RD FLOOR FOUNT	A	Y	N	Y	
		4650-9	1ST FLOOR MENS RM	A	Y	N	Y	
		4650DDBP13	WASTEWATER TP	A	Y	N	Y	Y
		4650DDBP14	1216 KING ST. #1	A	Y	N	Y	Y
		BMS-10	HOUSE #10	A	Y	N	Y	
		BMS-6	HOUSE #6	A	Y	N	Y	
		BMS-FOUNTAIN	WRESTLING RM FOUNTAIN	A	Y	N	Y	
		BMS-FOUNTAIN	GENERATED BY BATCH	A	Y			
		BMS-LADIES	POOL BLDG LADIES RM	A	Y	N	Y	
		BMS-MAIN	MAIN DPT TAP	A	Y	N	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10272	WELL A	2	WELL A	A	Y			
10273	WELL B	2	WELL B	A	Y			
53400	WELL C	2	WELL #3	A	Y			
60050	ATMOSPHERIC STORAGE							
966	WATER TREATMENT							

Certified Operator Information

Water System Facility: WATER TREATMENT (WSF ID: 966)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0579143	BRUNSWICK SCHOOL (LOWER & LOWER MIDDLE)	C	567	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1252 KING STREET						12	
Towns Served: GREENWICH							

Certified Operator Information

Water System Facility: **WATER TREATMENT (WSF ID: 966)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2025

Contact Information

Name		Organization			Job Title			
Mr. Thomas Philip		Brunswick Middle School			Head Master			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
100 Maher Ave						Greenwich	CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-625-5800				203-625-5800	Thomas_Philip@brunswickschool.org			

Contact Role(s): **Owner**

Name		Organization			Job Title			
Mr. Charles J. Redahan		Brunswick Middle School			Maintenance Super.			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1232 King Street						Greenwich	CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-625-5877	5877	203-625-5816		203-223-2526	credahan@brunswickschool.org			

Contact Role(s): **Administrative Contact**

Name		Organization			Job Title			
Mrs. Kathleen Harrington		Brunswick School, Inc.			Cfo & Business Mangr			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
100 Maher Road						Greenwich	CT	06830
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-625-5815		203-625-5816		203-223-2526	kharrington@brunswickschool.org			

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule