

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0460024	CHRIST CHURCH	NTNC	57	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD				1			

Towns Served: EASTON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Alkalinity (1927)	2 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Lead And Copper (PBCU)	5 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0460024	CHRIST CHURCH	NTNC	57	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD				1			

Towns Served: EASTON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
Start Date: 5/1/2023		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2024 - 12/31/2024	Y
		1/1/2025 - 1/31/2025	Y
		2/1/2025 - 2/28/2025	Y
		3/1/2025 - 3/31/2025	Y
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 7.5 PH	4
Start Date: 5/1/2023		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Operating Limit Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CC001	KIT SNK NEW SNK	A	Y	2	Y	
		CC002	KIT SNK OLD SNK	A	Y	2	Y	
		CC003	RR BOYS ROOM	A	Y	2	Y	
		CC004	RR GIRLS ROOM	A	Y	2	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0460024	CHRIST CHURCH	NTNC	57	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD				1			
Towns Served: EASTON							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CC005	PRESCHOOL 1	A	Y	2	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1739	CHRIST CHURCH TREATMENT PLANT							
20850	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: CHRIST CHURCH TREATMENT PLANT (WSF ID: 1739)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name		Organization			Job Title	
Ms. Victoria Markanthy		Christ Church of Easton			Senior Warden	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
59 Church Rd				Easton	CT	06612
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-268-3569				203-551-4728	eastonparish1762@sbcglobal.net	

Contact Role(s): **Legal Contact**

Name		Organization			Job Title	
Mr. David McCann		Christ Church of Easton			Buildings & Grounds	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
59 Church Road				Easton	CT	06612
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-268-3569					fiddledm50@aol.com	

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule