

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280011	TARIFFVILLE FIRE DISTRICT WATER DEPT	C	1,477	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			493	11			

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Coliform (3100) **3 repeat (RP) per period**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/7/25 - 1/12/25		Complete

Total Coliform (3100) **2 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Lead And Copper (PBCU) **10 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

Physical Parameters (PPS) **2 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280011	TARIFFVILLE FIRE DISTRICT WATER DEPT	C	1,477	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			493	11			

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELLS (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL 2 (WSF ID: 1258)

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	1/6/25 - 1/12/25		Complete

Water System Facility: WELL 3 (WSF ID: 1259)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280011	TARIFFVILLE FIRE DISTRICT WATER DEPT	C	1,477	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			493	11			

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 1259)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	1/6/25 - 1/12/25		Complete

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		TFD001	6 ELM ST	I	Y			
		TFD002	24 CRESTVIEW RD	I	Y		Y	
		TFD003	10 CHURCH ST	A	Y			
		TFD004	38 HAYES RD	I				
		TFD005	10 CRESTVIEW RD	I				
		TFD006	41 WEST POINT TERR	I				
		TFD007	15 WINTHROP ST	I				
		TFD008	30 CENTER ST	I				
		TFD009	30 WHITE WATER	A		1		
		TFD010	16 WOOD DUCK	A		1		
		TFD011	7 HARTLAND	I				
		TFD012	38 HAYES RD-KITCHEN	A	Y		Y	
		TFD013	26 WEST POINT TERR	A	Y			
		TFD014	8 CRESTVIEW RD	A	Y			
		TFD015	16 CHURCH ST	A	Y			
		TFD016	42 WEST POINT TERR	A	Y			
		TFD017	34 HAYES RD	A				
		TFD018	4 WEST POINT TERR	A				
		TFD019	32 HAYES RD	A				
		TFD020	49 WEST POINT TERR	A	Y			
		TFD-LEAD001	6 MALLARD CIRCLE	A		1		
		TFD-LEAD002	7 MALLARD CIRCLE	A		1		
		TFD-LEAD003	12 MALLARD CIRCLE	A		1		
		TFD-LEAD004	15 MALLARD CIRCLE	A		1		
		TFD-LEAD005	5 QUAIL DRIVE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280011	TARIFFVILLE FIRE DISTRICT WATER DEPT	C	1,477	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			493	11			

Towns Served: SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TFD-LEAD006	3 TANAGER CIRCLE	A		1		
		TFD-LEAD007	15 TANAGER CIRCLE	A		1		
		TFD-LEAD008	18 TANAGER CIRCLE	A		1		
		TFD-LEAD009	22 TANAGER CIRCLE	A		1		
		TFD-LEAD010	3 TEAL CIRCLE	A		1		
		TFD-LEAD011	8 TEAL CIRCLE	A		1		
		TFD-LEAD012	10 TEAL CIRCLE	A		1		
		TFD-LEAD013	4 WHITE WATER TURN	A		1		
		TFD-LEAD014	6 WHITE WATER TURN	A		1		
		TFD-LEAD015	19 WHITE WATER TURN	A		1		
		TFD-LEAD016	21 WHITE WATER TURN	A		1		
		TFD-LEAD017	38 WHITE WATER TURN	A		1		
		TFD-LEAD018	40 WHITE WATER TURN	A		1		
		TFD-LEAD019	10 WOOD DUCK LANE	A		1		
		TFD-LEAD020	11 WOOD DUCK LANE	A		1		
		TFD-LEAD022	22 WOOD DUCK LANE	A		1		
		TFD-LEAD023	23 WOOD DUCK LANE	A		1		
		TFD-LEAD024	28 WOOD DUCK LANE	A		1		
		TFD-LEAD025	30 WOOD DUCK LANE	A		1		
		TFD-LEAD026	44 WOOD DUCK LANE	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT-WELLS	A				
1257	WELL 1	2	WELL 1	A				
1258	WELL 2	2	WELL 2	A				
1259	WELL 3	2	WELL 3	A				
60775	TALCOTT MOUNTAIN TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BROWN, MICHAEL T	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2027
ROGERS, FREDERICK W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027

Contact Information

Name	Organization	Job Title		
Mr. Scott R. Madigan	Tariffville Fire District	President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
42 West Point Terrace		Tariffville	CT	06081

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280011	TARIFFVILLE FIRE DISTRICT WATER DEPT	C	1,477	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		493	11				
Towns Served: SIMSBURY							
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
			860-214-6586	860-651-4227	smadigan@vanzelm.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		15 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
Asbestos (1094)		7 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
W SIMSBURY PO (03331)	1/1/21 - 12/31/29		Complete		
HAMPDEN CIRCLE PS (03336)	1/1/21 - 12/31/29		Complete		
TOOTIN HILL S.S. (03350)	1/1/21 - 12/31/29		Complete		
ST. ALBANS S.S. (03351)	1/1/21 - 12/31/29		Complete		
CANTON RD S.S. (03359)	1/1/21 - 12/31/29		Complete		
SIMSBURY HIGH SS (03362)	1/1/21 - 12/31/29		Complete		
LATIMER LANE SS (03363)	1/1/21 - 12/31/29		Complete		
Tetrachloroethylene (2987)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25		Complete		
Total Coliform (3100)		15 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25		Complete		
	5/1/25 - 5/31/25		Complete		
	6/1/25 - 6/30/25		Complete		
	7/1/25 - 7/31/25		Complete		
	8/1/25 - 8/31/25		Complete		
	9/1/25 - 9/30/25		Complete		
	10/1/25 - 10/31/25		Complete		
	11/1/25 - 11/30/25		Complete		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
TOP VIEW DR P.S. (03353)	1/1/24 - 12/31/24	8/17-8/23	Complete		
	1/1/25 - 12/31/25	8/17-8/23	Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)			2 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26	8/17-8/23	
CANTON RD S.S. (03359)	1/1/24 - 12/31/24	8/17-8/23	Complete
	1/1/25 - 12/31/25	8/17-8/23	
	1/1/26 - 12/31/26	8/17-8/23	

Lead And Copper (PBCU)			60 routine (RT) per six months
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		

Physical Parameters (PPS)			15 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water Quality Parameters Orthophosphate, Total Alkalinity, T (WQP8)			20 routine (RT) per six months
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/24 - 12/31/24		Complete
	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		

Water System Facility: **WELLS #7 & #8 ENTRY POINT (WSF ID: 00708)**

Net Gross Alpha (4000)			1 routine (RT) per six years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELLS #7 & #8 TP POE (3)	1/1/20 - 12/31/25		
	1/1/26 - 12/31/31		

Uranium (4006)			1 routine (RT) per six years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELLS #7 & #8 TP POE (3)	1/1/20 - 12/31/25		
	1/1/26 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monitoring Requirements

Water System Facility: WELLS #7 & #8 ENTRY POINT (WSF ID: 00708)

Combined Radium-226/228 (4010)		1 routine (RT) per six years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #7 & #8 TP POE (3)	1/1/20 - 12/31/25				
	1/1/26 - 12/31/31				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #7 & #8 TP POE (3)	1/1/24 - 12/31/26				
	1/1/27 - 12/31/29				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #7 & #8 TP POE (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #7 & #8 TP POE (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				
Organic Chemicals (VOCS)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #7 & #8 TP POE (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				

Water System Facility: WELLS #2 & #5A – ENO PLACE ENTRY POINT (WSF ID: 00709)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #2 & #5A – ENO PLACE TP ENTRY POIN (3)	1/1/23 - 12/31/25		Complete		
	1/1/26 - 12/31/28				
Nitrate And Nitrite (NOX)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #2 & #5A – ENO PLACE TP ENTRY POIN (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #2 & #5A – ENO PLACE TP ENTRY POIN (3)	1/1/22 - 12/31/30				
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)		2 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELLS #2 & #5A – ENO PLACE TP ENTRY POIN (3)	1/1/23 - 12/31/25				
	1/1/26 - 12/31/28				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monitoring Requirements

Water System Facility: WELLS #2 & #5A – ENO PLACE ENTRY POINT (WSF ID: 00709)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELLS #2 & #5A – ENO PLACE TP ENTRY POIN (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL #1A,3,4,6 STRATTON BROOK ENTRY PT (WSF ID: 00710)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRATTON BROOK WELLFIELD ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRATTON BROOK WELLFIELD ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRATTON BROOK WELLFIELD ENTRY POINT (3)	1/1/22 - 12/31/30		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRATTON BROOK WELLFIELD ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
	1/1/28 - 12/31/30		

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
STRATTON BROOK WELLFIELD ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL #2 (WSF ID: 1260)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: WELL #3 (WSF ID: 1301)

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monitoring Requirements

Water System Facility: **WELL #3 (WSF ID: 1301)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #4 (WSF ID: 1302)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #4 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #6 (WSF ID: 1303)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #6 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #8 (WSF ID: 1305)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #8 (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **WELL #5A (WSF ID: 48262)**

E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #5A (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSFID: 00600)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Minimum: 7.0 PH	Daily
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: WELLS #7 & #8 ENTRY POINT (WSFID: 00708)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	<spaces> ()	Maximum: 2.0 MG/L	2
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility: WELLS #7 & #8 ENTRY POINT (WSFID: 00708)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
pH	<spaces> ()	Maximum: 7.8 PH	Daily
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 2.0 MG/L	2
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Phosphate (as PO4)	<spaces> ()	Maximum: 4.0 MG/L	2
Start Date: 4/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility: **WELLS #2 & #5A – ENO PLACE ENTRY POINT (WSFID: 00709)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 11/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.5 MG/L	2
Start Date: 11/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2
Start Date: 11/1/2021		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Water System Facility: **WELL #1A,3,4,6 STRATTON BROOK ENTRY PT (WSFID: 00710)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility: WELL #1A,3,4,6 STRATTON BROOK ENTRY PT (WSFID: 00710)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.5 MG/L	2
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.8 PH	Daily
Start Date: 4/1/2022		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		12/1/2024 - 12/31/2024	
		1/1/2025 - 1/31/2025	
		2/1/2025 - 2/28/2025	
		3/1/2025 - 3/31/2025	
		4/1/2025 - 4/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	03330	LATIMER LANE	I	Y			
		03331	W SIMSBURY PO	A	Y		Y	
		03332	MCLEAN HOME	A	Y			
		03333	ST ALBANS CHURCH	I	Y			
		03334	TOOTIN HILLS SCH	I	Y			
		03335	1225 HOPMEADOW ST	I	Y			
		03336	HAMPDEN CIRCLE PS	A	Y		Y	
		03336D	HAMPDEN CIRCLE PS -	A	Y			
		03336U	HAMPDEN CIRCLE PS -	A	Y			
		03337	HIGH SCHOOL	I	Y			
		03342	SOMERSET LANE	A	Y			
		03347	SOMERSET LA SS	A	Y			
		03348	TAMARACK LA SS	A	Y			
		03349	RIVERVIEW CIR SS	A	Y			
		03350	TOOTIN HILL S.S.	A	Y		Y	
		03350D	TOOTIN HILL SS - DOW	A	Y			
		03350U	TOOTIN HILL SS - UPS	A	Y			
		03351	ST. ALBANS S.S.	A	Y		Y	
		03351D	ST ALBANS SS - DOWNS	A	Y			
		03351U	ST ALBANS SS - UPSTR	A	Y			
		03352	127 HOPMEADOW ST	I	Y			
		03353	TOP VIEW DR P.S.	A	Y			Y
		03353D	TOP VIEW DR PS DOWNS	A				
		03353U	TOP VIEW DR PS UPSTR	A				
		03354	FRANK KEARNS SCHOOL	I	Y			
		03355	4 ROCKLYN DR	I	Y			
		03356	6 SMOKEY RIDGE RD	I	Y			
		03357	ROCKLYN DR. S.S.	A	Y		Y	
		03358	SMOKEY RIDGE DR S.S.	A	Y			
		03359	CANTON RD S.S.	A	Y		Y	Y
		03360	PINNACLE MT. P.S.	A	Y			
		03361	VILLAGE TANK #1	A	Y			
		03362	SIMSBURY HIGH SS	A	Y		Y	
		03363	LATIMER LANE SS	A	Y		Y	
		03364	1260 HOPMEADOW ST	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		03367	ENO PLACE SS	A			Y	
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB07965	3 OLD FARMS LANE	I		1		
		PB5976	3 TRAINOR DRIVE	A		1		
		PB5977	17 TRAINOR DR	A		1		
		PB5978	19 TRAINOR DRIVE	A		1		
		PB5979	6 TRAINOR DR	A		1		
		PB5980	8 TRAINOR DR	A		1		
		PB5981	16 TRAINOR DR	A		1		
		PB5982	20 TRAINOR DRIVE	A		1		
		PB5983	5 TRAINOR DRIVE	A		1		
		PB5984	14 TRAINOR DR	A		1		
		PB5985	4 TRAINOR DRIVE	A		1		
		PB5987	1 RIVRWALK WEATOGUE	A		1		
		PB5988	3 RIVRWALK WEATOGUE	A		1		
		PB5991	23 RIVRWALK WEATOGUE	A		1		
		PB5993	15 RIVRWALK WEATOGUE	A		1		
		PB5994	17 RIVRWALK WEATOGUE	A		1		
		PB5997	36 RIVRWALK WEATOGUE	A		1		
		PB5998	18 RIVRWALK WEATOGUE	A		1		
		PB5999	2 RIVRWALK WEATOGUE	A		1		
		PB6002	34 RIVRWALK WEATOGUE	A		1		
		PB6003	51 STRATTN FOREST WA	A		1		
		PB6004	57 STRATTON FOREST W	A		1		
		PB6005	63 STRATTON FOREST W	A		1		
		PB6006	43 STRATTON FOREST W	A		1		
		PB6007	53 STRATTON FOREST W	A		1		
		PB6008	59 STRATTON FOREST W	A		1		
		PB6010	55 STRATTON FOREST W	A		1		
		PB6012	41 STRATTON FOREST W	A		1		
		PB6013	45 STRATTON FOREST W	A		1		
		PB6014	65 STRATTON FOREST W	A		1		
		PB6015	51 CHRISWELL DRIVE	A		3		
		PB6016	26 OXFORD SIMSBURY	A		1		
		PB6018	24 OXFORD SIMSBURY	A		1		
		PB6252	11 REDSTONE DRIVE	A		3		
		PB6356	15 CRESCENT WAY	A		3		
		PB6357	3 RIVERVIEW CIRCLE	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6358	1 SURRY CIRCLE	A		3		
		PB6359	17 SAXTON BROOK DRIV	A		1		
		PB6360	1075 HOPMEADOW STREE	A		3		
		PB6361	54 REDSTONE DRIVE	A		3		
		PB6362	7 PINNACLE MTN ROAD	A		3		
		PB6363	3 ANDREW DRIVE	A		3		
		PB6364	21 CHESTNUT HILL ROA	A		3		
		PB6365	19 LITCHFIELD DRIVE	A		3		
		PB6366	11 SAXTON BROOK DRIV	A		1		
		PB6367	71 HOLCOMB STREET	A		3		
		PB6368	10 GRIFFIN STREET	A		1		
		PB6369	11 KINGS ROAD	A		3		
		PB6370	8 GRIFFIN STREET	A		3		
		PB7137	21 OX YOKE DRIVE	A		3		
		PB7138	5 AMY LANE	A		3		
		PB7139	8 AMY LANE	A		3		
		PB7140	6 AMY LANE	A		3		
		PB7141	122 W. MOUNTAIN RD.	A		3		
		PB7953	267 FIRETOWN RD	A		1		
		PB7954	280 FIRETOWN RD	A		1		
		PB7955	284 FIRETOWN RD	A		1		
		PB7956	292 FIRETOWN RD	A		1		
		PB7957	332 FIRETOWN RD	A		1		
		PB7958	336 FIRETOWN ROAD	A		1		
		PB7959	5 SAXTON BROOK DR	A		1		
		PB7960	7 SAXTON BROOK DR	A		1		
		PB7961	8 SAXTON BROOK DR	A		1		
		PB7962	12 SAXTON BROOK DR	A		1		
		PB7963	16 SAXTON BROOK DR	A		1		
		PB7964	1 OLD FARMS LANE	A		1		
		PB7965	3 OLD FARMS LANE	A		1		
		PB7966	2 OLD FARMS LANE	A		1		
		PB7967	2 ECHO LANE	A		1		
		PB7968	4 ECHO LANE	A		1		
		PB7969	6 ECHO LANE	A		1		
		PB7970	7 ECHO LANE	A		1		
		PB7971	9 ECHO LANE	A		1		
		PB7972	30 BUTTERNUT LANE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB7973	31 BUTTERNUT LANE	A		1		
		PB7974	32 BUTTERNUT LANE	A		1		
		PB7975	104 E. WEATOGUE ST	A		1		
		PB7976	109 E. WEATOGUE ST	A		1		
		PB7977	111 E. WEATOGUE ST	A		1		
		PB7978	15 GLEN RD	A		1		
		PB7979	3 CAMILLE LANE	A		1		
		PB7980	6 CAMILLE LANE	A		1		
		PB9058	1 SIMSCROFT PL	A		1		
		PB9059	1 STRATTON LN	A		1		
		PB9060	2 WHITE OAK LN	A		1		
		PB9061	2 EVERGREEN DR	A		1		
		PB9062	4 SUGAR HOLLOW LN	A		1		
		PB9063	5 SUGAR HOLLOW LN	A		1		
		PB9064	7 ELLIOT DR	A		1		
		PB9065	7 TIMBER RIDGE DR	A		1		
		PB9066	9 TIMBER RIDGE DR	A		1		
		PB9067	10 TIMBER RIDGE DR	A		1		
		PB9068	11 TIMBER RIDGE DR	A		1		
		PB9069	12 CASE CIR	A		1		
		PB9070	14 PINNACLE MOUNTAIN	A		1		
		PB9071	41 PINNACLE MOUNTAIN	A		1		
		PB9072	15 WESCOTT RD	A		1		
		PB9073	43 GREAT POND RD	A		1		
		PB9074	59 GREAT POND RD	A		1		
		PB9075	70 GREAT POND RD	A		1		
		PB9076	90 GREAT POND RD	A		1		
		PB9077	46 OWENS BROOK BLVD	A		1		
		PB9078	191 HOSKINS RD	A		1		
		PB9079	195 HOSKINS RD	A		1		
		PB9080	85 PLANK HILL RD	A		1		
		PB9081	96 PLANK HILL RD	A		1		
		PB9082	4 SOMERSET LN	A		1		
		PB9083	6 SOMERSET LN	A		1		
		PB9084	10 SOMERSET LN	A		1		
		PB9091	5 RIVERVIEW CIRCLE	A		3		
		PB9349	DISTRIBUTION SYSTEM	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00708	WELLS #7 & #8 ENTRY POINT	3	WELLS #7 & #8 TP POE	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00709	WELLS #2 & #5A – ENO PLACE ENTRY POINT	3	WELLS #2 & #5A – ENO	A				
00710	WELL #1A,3,4,6 STRATTON BROOK ENTRY PT	3	STRATTION BROOK WELL	A				
1260	WELL #2	2	WELL #2	A				
1301	WELL #3	2	WELL #3	A				
1302	WELL #4	2	WELL #4	A				
1303	WELL #6	2	WELL #6	A				
1305	WELL #8	2	WELL #8	A				
1306	WELL #7	2	WELL #7	A				
1749	WELLS #7 & #8 TREATMENT PLANT							
37016	TANK #1 (FIRETOWN TANK)							
37018	TANK #2 (TOP VIEW)							
37024	TANK #5 (CLIFDON TANK)							
48262	WELL #5A	2	WELL #5A	A				
51413	HIGH LEVEL #3 (HAMPDEN CIRCLE) HYDRO TAN							
51421	HIGH LEVEL #1 BOOSTER STATION							
51423	HIGH LEVEL #2 BOOSTER STATION							
51425	HIGH LEVEL #3 BOOSTER STATION							
51427	HIGH LEVEL #4 BOOSTER STATION							
51429	HIGH LEVEL #5 BOOSTER STATION							
51431	HIGH LEVEL #6 BOOSTER STATION							
62311	WELLS #2 & 5A TREATMENT PLANT							
62474	WELL #1A,3,4,6 STRATTON BROOK TREATMENT							
62590	WELL #1A	2	WELL #1A	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	

Towns Served: EAST GRANBY, GRANBY, SIMSBURY

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
FARRELLY, MARC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	8/26/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
HELMING, TRAVIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025

Water System Facility: WELLS #7 & #8 TREATMENT PLANT (WSF ID: 1749)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2025
FARRELLY, MARC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	8/26/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027

Water System Facility: WELLS #2 & 5A TREATMENT PLANT (WSF ID: 62311)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FARRELLY, MARC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	8/26/2024
HELMING, TRAVIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
HAVEL, DOUGLAS G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

Water System Facility: WELL #1A,3,4,6 STRATTON BROOK TREATMENT (WSF ID: 62474)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FARRELLY, MARC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	8/26/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
HELMING, TRAVIS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2025
HAVEL, DOUGLAS G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280021	AQUARION-SIMSBURY REGIONAL	C	14,691	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						5,747	
Towns Served: EAST GRANBY, GRANBY, SIMSBURY							

Contact Information

Name			Organization			Job Title			
Mr. John P. Walsh			Aquarion Water Company			Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
835 Main Street			Mail Stop 700			Bridgeport		CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com				

Contact Role(s): Legal Contact									
Name			Organization			Job Title			
Mr. Robert J. Ulrich			Aquarion Water Company of Ct			Vp-Supply & Utility			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Aquarion Water Company of Ct			505 Huntington St.			Shelton		CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com				

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280051	ETHEL WALKER SCHOOL	C	325	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			35				

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
Asbestos (1094)		1 routine (RT) per nine years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29				
Total Haloacetic Acids (2456)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
PHELPS KITCHEN (7385)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
Total Trihalomethanes (2950)		1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
103 SAND HILL KIT (7384)	1/1/24 - 12/31/24	8/1-8/31	Complete		
	1/1/25 - 12/31/25	8/1-8/31			
	1/1/26 - 12/31/26	8/1-8/31			
Total Coliform (3100)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		
	1/1/25 - 1/31/25		Complete		
	2/1/25 - 2/28/25		Complete		
	3/1/25 - 3/31/25		Complete		
	4/1/25 - 4/30/25				
	5/1/25 - 5/31/25				
	6/1/25 - 6/30/25				
	7/1/25 - 7/31/25				
	8/1/25 - 8/31/25				
	9/1/25 - 9/30/25				
	10/1/25 - 10/31/25				
	11/1/25 - 11/30/25				
Lead And Copper (PBCU)		5 routine (RT) per three years			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	Complete		
	1/1/25 - 12/31/27	6/1-9/30			
Physical Parameters (PPS)		1 routine (RT) per month			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	12/1/24 - 12/31/24		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280051	ETHEL WALKER SCHOOL	C	325	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			35				

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 1/31/25		Complete
	2/1/25 - 2/28/25		Complete
	3/1/25 - 3/31/25		Complete
	4/1/25 - 4/30/25		
	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280051	ETHEL WALKER SCHOOL	C	325	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			35				

Towns Served: SIMSBURY

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Organic Chemicals (VOCS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	10/1/24 - 12/31/24			
	1/1/25 - 3/31/25		Complete	
	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25			

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily	
Start Date: 12/1/2024		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024	Y	
		1/1/2025 - 1/31/2025	Y	
		2/1/2025 - 2/28/2025	Y	
		3/1/2025 - 3/31/2025	Y	
		4/1/2025 - 4/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2	
Start Date: 4/1/2008		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2024 - 12/31/2024		
		1/1/2025 - 1/31/2025		
		2/1/2025 - 2/28/2025		
		3/1/2025 - 3/31/2025		
		4/1/2025 - 4/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	1/11/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1280051	ETHEL WALKER SCHOOL	C	325	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			35				

Towns Served: SIMSBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
		7376	HENDERSON SHOP	A		3			
		7377	CLUETT KITCHEN	A		3			
		7378	CLUETT RM 112 BATH	A					
		7379	SMITH HOUSE KITCHEN	A			3		
		7380	SMITH BATH RM4	A					
		7381	GAILBRAITH MENS RM	A					
		7382	BEAVER BROOK KITCHN	A		Y	3		
		7383	DRINKING FOUNT BB	A					
		7384	103 SAND HILL KIT	A			3		Y
		7385	PHELPS KITCHEN	A					Y
		7386	WELL HOUSE	A			Y		
				DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
1837	WELL	2	WELL	A					
36525	TREATMENT PLANT								
54714	INTERCONNECTION - CT1280021 - AQUARION								
60252	ATMOSPHERIC TANKS								
PS01	PUMP STATION								

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 36525)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Contact Information

Name		Organization			Job Title		
Mr. Richard F. Meier		Ethel Walker School			Facilities Director		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
230 Bushy Hill Rd					Simsbury	CT	06070
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-408-4349				203-444-0945	rmeier@my.ethelwalker.org		
Contact Role(s):		Legal Contact					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT1280051	ETHEL WALKER SCHOOL	C	325	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		35						
Towns Served: SIMSBURY								
Name			Organization			Job Title		
Mr. Tom Dimartino			Ethel Walker School			Dir of Facilities		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
230 Bushy Hill Rd						Simsbury	CT	06070
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-408-4467					tdimartino@my.ethelwalker.org			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule