

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300014</b>	<b>CHURCH OF THE EPIPHANY</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
276 MAIN STREET NORTH				1			
Towns Served: SOUTHBURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

**Water System Facility: WELL (WSF ID: 22173)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL (2)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Total Coliform Status</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300014</b>	<b>CHURCH OF THE EPIPHANY</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
276 MAIN STREET NORTH				1			
Towns Served: SOUTHBURY							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		COE001	RR 1ST FLOOR	A	Y		Y	
		COE002	RR 1ST FLR HANDICAP	A	Y		Y	
		COE003	1ST FLOOR SACRISTY	A	Y		Y	
		COE004	KIT SNK 1ST FLOOR	A	Y		Y	
		COE005	KIT HAND SNK 1ST FLR	A	Y		Y	
		COE006	KIT SNK DBL 1ST FLR	A	Y		Y	
		COE007	RR 2ND FLOOR	A	Y		Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22173	WELL	2	WELL	A				
60405	TREATMENT PLANT							

### Contact Information

Name		Organization			Job Title		
<b>Church of The Epiphany</b>							
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
290 Pratt St		Box 52			Meriden	CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-639-3501		203-235-1008					
Contact Role(s): <b>Owner</b>							
Name		Organization			Job Title		
<b>Mrs. Ginny Kowalski</b>		Church of The Epiphany			Sr. Warden		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
262 Main Street N					Southbury	CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-264-8150				203-264-8150	epiphanysbysby@att.net		
Contact Role(s): <b>Legal Contact</b>							
Name		Organization			Job Title		
<b>Mrs. Cynthia Boisits</b>		Church of The Epiphany			Church Administrator		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
262 Main Street N					Southbury	CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-264-8150				203-565-4339	epiphanysbysby@att.net		
Contact Role(s): <b>Administrative Contact</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
<b>CT1300014</b>	<b>CHURCH OF THE EPIPHANY</b>	NC	25	P	GW	
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
276 MAIN STREET NORTH			1			
Towns Served: <b>SOUTHBURY</b>						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1300034	MIRANDAS PIZZA & RESTAURANT	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1056 MAIN STREET SOUTH				1			
Towns Served: SOUTHURY							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

Water System Facility: **WELL (WSF ID: 22175)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL (2)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli	10/10/18 - 12/7/18	3	1/2/2020		1/12/2020	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300034</b>	<b>MIRANDAS PIZZA &amp; RESTAURANT</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1056 MAIN STREET SOUTH				1			
Towns Served: SOUTHURY							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
22175	WELL	2	WELL	A				
57039	TREATMENT PLANT							

## Contact Information

Name			Organization			Job Title			
<b>Mr. Qevsere Krivca</b>			Miranda's Restaurant			Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1056 Main Street						Southbury		CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-262-6400									

Contact Role(s): **Administrative Contact**

Name			Organization			Job Title			
<b>Gony, LLC</b>									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1056 Main Street						Southbury		CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				

Contact Role(s): **Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300064</b>	<b>KETTLETOWN S.P./BEACH WELL</b>	NC	167	S	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1434 GEORGE HILL ROAD				1			
Towns Served: SOUTHBURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			

<b>Physical Parameters (PPS)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>		<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24			Complete
	1/1/25 - 12/31/25			
	1/1/26 - 12/31/26			

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SEASONAL START UP COMPLETION	5/1/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	101	WOMENS BATHROOM	A	Y			
		102	MENS BATHROOM	A	Y			
		103	OUTSIDE FAUCET	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22178	WELL	2	WELL	A				

## Contact Information

Name			Organization			Job Title			
<b>Mr. David Cooley</b>			Deep-Engineering Unit			Supv Civil Engineer			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
163 Great Hill Road						Portland		CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-424-4120		860-344-2560	860-205-7552	860-424-3333	david.cooley@ct.gov				
Contact Role(s): <b>Legal Contact, Owner</b>									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1300064</b>	<b>KETTLETOWN S.P./BEACH WELL</b>	NC	167	S	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
1434 GEORGE HILL ROAD				1				
Towns Served: SOUTHBURY								
Name			Organization			Job Title		
<b>Ms. Andrea M. Lane</b>			State of CT Deep					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
163 Great Hill Road						Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-977-9739				860-424-3333	andrea.lane@ct.gov			

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300074</b>	<b>KETTLETOWN S.P./CAMPGROUND WELL</b>	NC	167	S	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
175 QUAKER FARMS ROAD			10				
Towns Served: SOUTHURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			

<b>Physical Parameters (PPS)</b>				<b>1 routine (RT) per quarter</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25			
	7/1/25 - 9/30/25			

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/24 - 12/31/24	4/1-9/30	Complete	
	1/1/25 - 12/31/25	4/1-9/30		
	1/1/26 - 12/31/26	4/1-9/30		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SEASONAL START UP COMPLETION	5/1/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	101	WOMENS BATHROOM	A	Y			
		102	MENS BATHROOM	A	Y			
		103	OUTSIDE FAUCET	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22179	WELL	2	WELL	A				
60810	ATMOSPHERIC STORAGE							

## Contact Information

Name			Organization			Job Title		
Mr. David Cooley			Deep-Engineering Unit			Supv Civil Engineer		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
163 Great Hill Road						Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-424-4120		860-344-2560	860-205-7552	860-424-3333	david.cooley@ct.gov			
Contact Role(s): <b>Legal Contact, Owner</b>								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1300074</b>	<b>KETTLETOWN S.P./CAMPGROUND WELL</b>	NC	167	S	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
175 QUAKER FARMS ROAD			10					
Towns Served: SOUTHBURY								
Name			Organization			Job Title		
<b>Ms. Andrea M. Lane</b>			State of CT Deep					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
163 Great Hill Road						Portland	CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-977-9739				860-424-3333	andrea.lane@ct.gov			

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1300164	SOUTH BRITAIN CONGREGATIONAL CHURCH	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
693 S BRITAIN RD				1			
Towns Served: SOUTHBURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

**Water System Facility: WELL (WSF ID: 22188)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL (2)	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22188	WELL	2	WELL	A				
59203	TREATMENT PLANT							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300164</b>	<b>SOUTH BRITAIN CONGREGATIONAL CHURCH</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
693 S BRITAIN RD				1			
Towns Served: SOUTHBURY							

## Contact Information

Name			Organization			Job Title			
<b>Ms. Cathy Somers</b>			South Britain Congregational C			Chair of Property			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Chair of Property			PO Box 64			Southbury		CT	06487
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-264-5890					sbcc_secretary@yahoo.com				

Contact Role(s): **Administrative Contact**

Name			Organization			Job Title			
<b>Mr. Ken Bolin</b>			South Britain Congregational C			Chair of Council			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Chair of Church Council			PO Box 64			Southbury		CT	06487
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-264-5890					sbcc_secretary@yahoo.com				

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300174</b>	<b>OLD COUNTRY STORE DELI LLC</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
667 SOUTH BRITAIN ROAD						1	
Towns Served: SOUTHBURY							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OCS001	HAND SINK LEFT	A	Y		Y	
		OCS002	HAND SINK RIGHT BACK	A	Y		Y	
		OCS003	TRIPLE SINK	A	Y		Y	
		OCS004	GENERIC RR	A	Y		Y	
	UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A				
22189	WELL	2	WELL	A				

## Contact Information

Name			Organization			Job Title			
Mr. Koco Pela			Old Country Store Deli, LLC			Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
667 South Britain Rd						Southbury		CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-264-3045				203-228-3440	kocopela@shcolohal.net				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300174</b>	<b>OLD COUNTRY STORE DELI LLC</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
667 SOUTH BRITAIN ROAD						1	
Towns Served: SOUTHBURY							
203 207 3075      203 220 3770      kcooper@dph.state.ct.us							
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300284</b>	<b>SOUTHFORD CORNER, LLC</b>	NC	47	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1455 SOUTHFORD ROAD				1			
Towns Served: SOUTHBURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	10/1/17 - 12/31/17	3	3/6/2019		3/16/2019	
Physical Parameters M&R Violation	10/1/17 - 12/31/17	3	3/6/2019		3/16/2019	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM	A				
			UPSTREAM	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22196	WELL	2	WELL	A				

## Contact Information

Name		Organization			Job Title			
<b>Mr. Christos Gogas</b>					Owner			
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
77 Hidden Brook Dr					Southbury		CT	06488

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300284</b>	<b>SOUTHFORD CORNER, LLC</b>	NC	47	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1455 SOUTHFORD ROAD				1			
Towns Served: SOUTHBURY							
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-560-9591					cgogas@aol.com		
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							
<b>Please note the following:</b>							
<ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>							

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300384</b>	<b>SPLASH CAR WASH</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
53 BULLET HILL ROAD				2			
Towns Served: SOUTHURY							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

**Water System Facility: ENTRY POINT - CAR WASH (WSF ID: 00701)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - CAR WASH (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

**Water System Facility: WELL 2 (CAR WASH) (WSF ID: 58855)**

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (CAR WASH) (2)	10/1/24 - 12/31/24		Complete
	1/1/25 - 3/31/25		Complete
	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	4/17/2025	
RESPOND TO SANITARY SURVEY	4/17/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1300384</b>	<b>SPLASH CAR WASH</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
53 BULLET HILL ROAD				2			
Towns Served: SOUTHBURY							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SCW001	CAR WASH RR LOBBY	A	Y		Y	
		SCW002	CAR WASH GARAGE RR	A	Y		Y	
		SCW003	CAR WASH OFFICE RR	A	Y		Y	
		SCW004	DETAIL LOBBY RR	A	Y		Y	
		SCW005	DETAIL APT 1 KIT	A	Y		Y	
		SCW006	DETAIL APT 1 RR	A	Y		Y	
		SCW007	DETAIL APT 2 KIT	A	Y		Y	
		SCW008	DETAIL APT 2 RR	A	Y		Y	
		SCW009	CAR DETAIL SHOP	A	Y			
		SCW010	CAR WASH	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM CW	CWRRLOBBY - CAR WASH	A	Y			
00701	ENTRY POINT - CAR WASH	3	EP - CAR WASH	A				
58855	WELL 2 (CAR WASH)	2	WELL 2 (CAR WASH)	A				
58859	TREATMENT PLANT							

## Contact Information

Name		Organization			Job Title		
<b>Mr. Bill Cummings</b>		Bullet Hill Realty			Owner		
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
111 Pomperaug Trail					Southbury	CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-592-7002					bc111@att.net		
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1301124</b>	<b>CHRIST THE SAVIOR ORTHODOX CHURCH</b>	NC	150	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1070 ROXBURY ROAD				1			
Towns Served: SOUTHURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
48941	WELL 1	2	WELL 1	A				

## Contact Information

Name			Organization			Job Title			
Mr. Rev. Vladimir Aleandro			Christ The Savior Orthodox Chu						
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1070 Roxbury Road						Southbury		CT	06798
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-267-1330				203-267-1330					
Contact Role(s): <b>Legal Contact, Owner</b>									

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

## Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT1301124</b>	<b>CHRIST THE SAVIOR ORTHODOX CHURCH</b>	NC	150	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
1070 ROXBURY ROAD				1				
Towns Served: SOUTHBURY								
Name			Organization			Job Title		
<b>Mr. Moses Locke</b>			Christ The Savior Orthodox Chu					
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1070 Roxbury Road						Southbury	CT	06798
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
			603-832-6791		Frmoseslocke@gmail.com			
Contact Role(s): <b>Administrative Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1301144	CHURCH OF LATTER DAY SAINTS, SOUTHBURY	NC	121	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1021 ROXBURY ROAD				1			
Towns Served: SOUTHBURY							

### Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00501	WELL #1	2	WELL #1W	A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
			DOWNSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
59491	HYDROPNEUMATIC TANK							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1301144</b>	<b>CHURCH OF LATTER DAY SAINTS, SOUTHBURY</b>	NC	121	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1021 ROXBURY ROAD				1			
Towns Served: SOUTHBURY							

## Contact Information

Name				Organization			Job Title	
<b>Ms. Christine Spencer</b>				Church of Jesus Christ of Lds			Hartford Admin Asst	
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
130 South St						Cromwell	CT	06516
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-635-4035		860-835-4036			spencerca@churchofjesuschrist.org			

Contact Role(s): <b>Administrative Contact</b>								
Name				Organization			Job Title	
<b>Mr. Andrew Beecher</b>				Church of Jesus Christ of Lds			Drinking Water	
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
50 E North Temple St			Attn: Andrew Beecher 12Th Floor			Salt Lake City	UT	84150
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
801-240-1693				435-230-9658	drinkingwater@churchofjesuschrist.org			

Contact Role(s): **Legal Contact, Owner**

- Please note the following:**
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
  2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
  3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1301154	WHEELS STORE NO. 14	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1411 SOUTHFORD RD						1	
Towns Served: SOUTHBURY							

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25		Complete		
	1/1/26 - 12/31/26				

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Physical Parameters M&R Violation	10/1/23 - 12/31/23	3	6/6/2025		6/16/2025	
Total Coliform M&R Violation	10/1/23 - 12/31/23	3	6/6/2025		6/16/2025	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CSS1	COFFEE ISLAND SINK	A	Y		Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		ES1B	WASH SINK 1	A	Y		Y	
		ES2B	WASH SINK 2	A	Y		Y	
		FS1A	TAP BY WATER FILTER	A	Y		Y	
		LR1	WOMENS ROOM SINK	A	Y		Y	
		MB1	MENS ROOM SINK	A	Y		Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WS2B	KITCHEN WASH SINK	A	Y		Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1301154</b>	<b>WHEELS STORE NO. 14</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1411 SOUTHFORD RD						1	
Towns Served: SOUTHBURY							

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
60926	WELL 1	2	WELL #1	A				

## Contact Information

Name			Organization			Job Title			
<b>Mr. Jeff McCullough</b>			Global Partners, Lp			Env. Project Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 549290			800 South Street, Suite 500			Waltham		MA	02453
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
781-250-7369					jeff.mccullough@globalp.com				

Contact Role(s): **Legal Contact**

Name			Organization			Job Title			
<b>Mr. Jack Cerra</b>			Atlas Technical Consultants			Sr Environmental Tec			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
290 Roberts Street			Suite 301			East Hartford		CT	06108
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-614-1983					jack.cerra@oneatlas.com				

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1301164</b>	<b>CALVARY FELLOWSHIP SOUTHBURY</b>	NC	540	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
354 KETTLETOWN RD, SOUTHBURY						1	
Towns Served: SOUTHBURY							

## Monitoring Requirements

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	10/1/24 - 12/31/24		Complete		
	1/1/25 - 3/31/25		Complete		
	4/1/25 - 6/30/25				
	7/1/25 - 9/30/25				
	10/1/25 - 12/31/25				

**Water System Facility: ENTRY POINT (WSF ID: 00700)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete		
	1/1/25 - 12/31/25				
	1/1/26 - 12/31/26				

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		CFS001	CAFE SINK	A	Y			
		CFS002	LADIES RR L, R	A	Y			
		CFS003	MEN RR L,R	A	Y			
		CFS004	NURSERY SINK	A	Y			
		CFS005	CHILDRENS BOYS SINK	A	Y			
		CFS006	CHILDRENS GIRLS SINK	A	Y			
		CFS007	JANITOR CLOSET SINK	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62329	WELL 1	2	WELL 1	A				

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT1301164</b>	<b>CALVARY FELLOWSHIP SOUTHBURY</b>	NC	540	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
354 KETTLETOWN RD, SOUTHBURY						1	
Towns Served: SOUTHBURY							

## Contact Information

Name			Organization			Job Title			
<b>Mr. John Eastwood</b>			Calvary Southbury			Lead Pastor			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
134 Main St. South						Southbury		CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-267-5441				203-267-5441	john@calvarysouthbury.com				

Contact Role(s): **Owner**

Name			Organization			Job Title			
<b>Pastor Mark W. Grasso</b>			Calvary Fellowship Southbury			Pastor of Outreach			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
354 Kettletown Rd.						Southbury		CT	06488
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-267-5441					mark@calvarysouthbury.com				

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**